

QUOTED DATE 11/18/20

GREEN COVE SPRINGS COPY



SHIP TO:
CITY OF GREEN COVE SPRINGS
900 GUM STREET

GREEN COVE SPRINGSFL32043

<u>DESCRIPTION</u>	<u>PRODUCT NUMBER</u>	<u>QTY</u>	<u>UNIT PRICE</u>	<u>EXT PRICE</u>
--------------------	-----------------------	------------	-------------------	------------------

TRANSFORMER LOSS DATA IS BASED ON ANSI C57.12.00:

LOSS GRT: AVE VOLT% : 100

NL TEMP BASIS: 85 LL TEMP BASIS: 85

FOB GREEN COVE SPRINGS, FL.

FREIGHT PREPAID AND ALLOWED.

LEAD TIME 18-20 WEEKS.

*QUOTED PER ERMCO THREE PHASE REQUEST FOR QUOTATION FORM.

-DUE TO PRIMARY VOLTAGE REQUEST, QUOTED WITH 125 BIL IN LIEU OF 95 BIL.

-QUOTED WITH SPECIFIC DIMENSIONS. ERMCO PROVIDES SPECIFIC DIMENSIONS FOR UNITS 750 KVA AND LARGER.

-TAPS ARE DESIGNED FOR USE IN THE SERIES POSTION ONLY.

NOTE: LEADTIME

IS SUBJECT TO CHANGE WITHOUT NOTICE! 4TH QTR INDEX 2020. FREIGHT PREPAID & ALLOWED. LEAD TIME FOR SINGLE PHASE POLES 14-16 WKS-PADS 22-24 WKS ARO 3 PHASE PAD 18-20 WKS ARO

ITEM 1	ERMCO 3 PHASE PAD TRANSFORMER	3PH-PAD	2	\$26800.00	\$53600.00
--------	-------------------------------	---------	---	------------	------------

ITEM# : 1.00
NL= 2190 LL=10966 IZ=6.000 TL=13156

OPTIONS BEGIN.....

ERMCO	ERMCO STD 3PH TRANSFORMER
2000	2000 KVA
G	GRDY
167G	13200GY/7620X22860GY/13200 125 BIL
X	H0/X0 GROUND
003	2 TAPS 2.5% ABOVE & BELOW NORMAL
127	480Y/277 LH
S5	ANSI SPECIFIC K DIM=5.0
L	LOOP FEED

QUOTED DATE 11/10/20

GREEN COVE COPY



SHIP TO:
CITY OF GREEN COVE SPRINGS
900 GUM STREET

GREEN COVE SPRINGSFL32043

<u>DESCRIPTION</u>	<u>PRODUCT NUMBER</u>	<u>QTY</u>	<u>UNIT PRICE</u>	<u>EXT PRICE</u>
010	ERMCO STD REPLACABLE STUD WELL			
G15	STD INSERT SYSTEM SELECT			
000	ELBOW ARRESTERS NOT SELECTED			
000	NO INS. STANDOFF BUSHING SELECTED			
000	NO INS. PROTECTIVE CAP SELECTED			
S	STAGGERED LV BUSHING ARRANGEMENT			
510	HJ INTG 10H SPD			
1	LV BUSHING SUPPORTS REQUIRED			
361	HI-AMP "BAYO" FUSE/LINK CP			
A00	STD ISOLATION LINK BY CONFIGURATOR			
1	FLAPR BAYO HOLDR W/SILVER CONTACTS			
000	MILD STEEL TANK & BASE			
000	MILD STEEL CABINET & SILL			
0	STD CABINET PARTITION			
0	PADMOUNT GREEN FINISH			
2	SS HARDWARE W/BRONZE NUTS			
11	SILICON BRONZE PENTABOLT			
1	S.S. 2HOLE GRD PAD IN PRI & SEC			
00	STANDARD AIR SPACE			
00	GENERIC PR VALVE .25 10PSI 35SCFM			
Z	ERMCO STD DRAIN VALVE W/ SAMPLER			
P	DRAIN IN PRIMARY COMPARTMENT			
0	1"NPT FILL PLUG			
Z	SEC ERMCO STD LIQUID LEVEL GAUGE			
0	NO VACUUM GAGE SELECTED			
Z	ERMCO STD TEMPERATURE GAGE			
0	STD TX OIL			
A	STANDARD TWO NAMEPLATES			
00	STD KVA DECAL OUTSIDE			
01	"NON PCB" 1X2 (ERMCO STD) 7-15			
11	DANGER "MR OUCH" GENERIC (3-52-02)			
02	WARNING "MR OUCH" GENERIC(3-52-01)			
99	STD PRIMARY DECAL INSIDE(HV)			
97	STD SEC DECAL OUTSIDE 1"			
00	STD ERMCO "E" LOGO DECAL (3-8-151)			
N	NO SPECIAL TEST NEEDED			
OPTIONS END.....				

48 HOUR NOTICE

RECEIVING HOURS 8 AM - 3 PM

NO FRIDAY DELIVERIES