


MEMO 22-01

TO: Susan Como, Assistant City Administrator

FROM: James Kowalski, Director of Public Services

DATE: January 26, 2022

SUBJECT: Sump Pump Replacement at Torrey Road Pump Station



Torrey Road Pump Station has a sump pump that is used for emergencies only that evacuates water accumulated after a pump failure. There is an early detection alarm for water accumulating on the third floor which is approximately 33 feet below the station. Once the water begins to fill up the third floor, this sump pump begins to pump the water upward of 33 feet plus an additional six to eight feet over to one of the pits.

The current sump pump is 17 years old and needs to be replaced. The seals and dynamics have eroded over the years.

The city requested and received the following quotes to replace the sump pump at Torrey Road Pump Station.


Detroit Pump	\$7,440.21
Kerr Pump & Supply	\$7,712.00
Kennedy Industries, Inc.	\$10,510.00

Detroit Pump has provided the city with excellent service over the years and has completed other repairs at the Torrey Road Pump Station.

Therefore, I am requesting Council to authorize the replacement of the sump pump at Torrey Road Pump Station from Detroit Pump, 23751 Amber Avenue, Warren, MI 48089 in the amount of \$7,440.21. I further recommend a repair contingency in an amount not to exceed \$2,000.00 for any unforeseen problems should they arise. The total project will not exceed \$9,440.21. This is a budgeted item included in the 2021/2022 fiscal year budget in the Pump Station Contractual Services account no. 592-542-818.000.

I do not believe any benefit will accrue to the City by seeking further bids. Approved for Council consideration.



Susan Como, Assistant City Administrator


Date

Fund Certification:

Account numbers and amounts have been verified as presented.


Steven Schmidt, Deputy Comptroller/Treasurer


Date



23751 Amber Avenue
Warren, MI 48089
248-544-4242
www.detroitpump.com

QUOTE

Quotation Date: 01/25/22
Company Name: City Grosse Point Woods
Contact Name: Ed Hall
Contact Phone: 313-343-2464

Prepared By: Raymond Lim
Account Manager: Wally Deaton
Job Name/Ship To: N/A
Contact E-Mail: ehall@gpwwmi.us

Item	Description/Part Number	QTY	Net Each	Total Net
1	XFP 100C-CB1 3/230V 4.7HP 1780RPM Motor With 65' Cable. Also equipped with Portable Stand and 3" Short Radius Flanged Elbow. Supplied with Seal Fail Relay for Moisture leakage and Overtemp.	1	\$ 5,955.21	\$ 5,955.21
2	Simplex Control Panel with On/Off Switch. Will Contain Seal Fail/Overtemp Relay, Main Power Distribution Blocks, Full Voltage IEC Rated Contactor, Pump Run Light, 120VAC Control Transformer.	1	\$ 1,485.00	\$ 1,485.00
Total:				\$ 7,440.21

Notes & Comments:

Delivery ARO: 3-5 Weeks
Shipping Terms: PPA Best Way

Raymond Lim

248 336-5206

Terms of Payment: Net 30 Days (with approved credit)
F.O.B.: Shipping Point
Freight: Not Included (UPS Prepaid & Add, Truck Collect)
Subject to Detroit Pump Terms & Conditions
Quote valid for 60 Days

Taxes: Not Included (Exempt Form Required for Non Tax Sales)
Start-Up: Not Included
Warranty: Standard Factory

HydroDynamics
INC.