MCKENNA



Memorandum: Exterior Lighting

TO: Grosse Pointe Woods Planning Commission

FROM: Brigitte Smith Wolf, AICP

SUBJECT: Exterior Lighting ZO Language

DATE: April 19, 2024

This memorandum provides language to consider adding to the Zoning Ordinance to better regulate and set guidance on exterior lighting. Information summarizing current lumen levels along the Mack Avenue Corridor is still included in this memo.

DEFINITIONS:

Lumens – A measurement of light emitted by a source. It can be LED, fluorescent, halogen or incandescent. Also known as "brightness" or "light output." Reference point: A standard 100-watt incandescent light bulb produces about 1,500 – 1,700 lumens.

Footcandles – A unit of illumination: defined as one lumen per square foot.

CURRENT LIGHTING LEVELS

A second field study of light levels was conducted. It is difficult to single out illuminated signs, internally illuminated and backlighting, to monitor by footcandle measurements.

Notable footcandle measurements include (averages; FC = footcandle):

- Point Vision (block north of Champs) has an illuminated and backlit sign = 1 FC at sidewalk
- Qamaria Yemeni Coffee green backlit sign and porch lighting = 7 FC at entrance, 1 FC at sidewalk

Additional footcandle measurements, from previous field studies, taken along the corridor at several commercial properties along Mack Avenue, include the following findings:

- Streetlights at boulevard = 1 FC
- Ornamental post lights at boulevard = 5 FC
- US/American Mattress
 - 9 FC at corner of Mack and Huntington.
 - 9 to 15 FC along the Mack Ave. sidewalk.
- Crispelli = 15 FC along sidewalk, just as US Mattresses.
- Bucharest Grill (These have changed not, since the Building Department had the facility include further shielding to the exterior parking lot lights.)
 - o 12 FC along front sidewalk.
 - o 8 FC parking lot.
 - o 0.7 FC at sidewalk along Torrey and near the parking lot entrance.
 - The parking lot light fixtures were shielded as they define the very definition of "light trespassing".
 From the Torrey sidewalk/street, people should not be able to look directly at the fixtures themselves.



- A nearby corner gas station averaged 5 FC along the outside edges of the pumps, and 20 FC directly beneath the canopy covering the cars and pumps.
- Much of the business corridor lighting at other cities our Building Official has tested were well below the
 13 FC average of the readings taken on Mack between Torrey and Huntington.
- The three parking lots recently tested at the City of Berkley yielded high averages of 10 FC and low of 5 FC with 1 FC along the sidewalks.

ZONING ORDINANCE STANDARDS

Section 50-6.1. Site Plan G. Preparation and contents of site plan does allow for the Building Department or Planning Commission to request a more detailed lighting plan and/or photometric study to assure adequate protection of surrounding properties.

ZONING ORDINANCE PROPOSED ADDED LANGUAGE

We propose exterior lighting standards be added to **Article 5 – Site Standards** as a new section: **50-5.22 Exterior Lighting.** The addition would read as the following...

###

50-5.22 Exterior Lighting

The purpose of this section is to protect the health, safety, and welfare of the public by encouraging lighting practices and systems that will minimize glare and light trespass while recognizing the need for buildings and sites to be illuminated for safety, security, visibility, and enhancement. This section provides standards for exterior lighting with measurable indicators to improve visibility and minimize nighttime lighting disturbances more consistently and proactively.

A. Regulating Illumination Levels by Footcandles. Existing and proposed lights may not exceed the following maximum intensity levels (measured at a height of 5-feet above grade).

Location/Use	Maximum Level of Illumination (footcandles "fc")
Overall average for the site	5.0 fc
At any point within the site	10.0 fc
At rear property line	0.5 fc
At the public right of way / sidewalk along the front property line, for properties with building setback 5 feet or less	5.0 fc
At the public right of way / sidewalk along the front property line, for properties with buildings of a front setback greater than 5 feet	1.0 fc
Gas Station (under canopy only)	20.0 fc

B. Shielding. All exterior lighting, excluding accent lighting in residential districts, must be fully cut off and shielded so the surface of the source of the light is not visible, and is directed downward and shielded away from adjacent properties, with consideration to protecting residential uses.



- C. Non-Essential Lighting. Non-essential lighting must be turned off after business hours, except for the minimum necessary security lighting. The use of a motion detector or other automatic timing system of security lighting is encouraged.
- D. Consistent Fixtures. The type and design of lighting must be consistent throughout a site.
- E. Impact. Lighting must be arranged so as to not adversely affect driver visibility on rights-of-way.
- F. Decorative Lighting. Buildings within the C and C-F districts must feature decorative lighting on all façades which face the public right-of-way. Wall pack type lighting is prohibited.
- G. Gas Station Lighting. Lighting under gas station canopies is limited to fully recessed lighting fixtures.
- H. Sign Lighting. Illuminated signs must comply with the footcandle measurements of the overall site and cannot cause the site to exceed the maximum allowable footcandles at any point within the site or from the public right-of-way.
- I. Exempt Lighting. The following are exempt from the requirements of this Article:
 - a. Required exit signs and safety lights for stairs and ramps.
 - b. Temporary holiday lights (provided that such lighting is installed no more than 60-days prior to, and 30 days following, the holiday such decorations represent).
 - c. Lights required by the Federal Aviation Administration, or other federal or state agency.
 - d. Interior lights.
 - e. Temporary lights necessary for construction or emergencies.
- J. Prohibited Lighting. The following lights are prohibited:
 - a. Rope lights (including neon, except when used in outlined tubing signs) around and within window and door openings.
 - b. Aerial lasers and/or "searchlight" style lights.
 - c. Flashing, moving, or intermittent lights (including lighting that changes colors).
 - d. Other intense lights, defined as having a light source exceeding 3,000 lumens per fixture.
- K. Special Exception Lighting.
 - a. Lighting systems not complying with the requirements of this Article, but consistent with its intent, may be considered by the Planning Commission, subject to special land use approval. This includes instances of: a) Sport fields and stadiums. b) Public monuments, public buildings, government facilities, and religious institutions. c) Any other lighting application determined to be appropriate by the Planning Commission. 2)
 - b. The Planning Commission must find that the proposed lighting will not create unwarranted glare, sky glow, or light trespass. The applicant must demonstrate that every reasonable effort has been made to mitigate obtrusive light and artificial sky glow, supported by a signed statement from a registered engineer or by a lighting certified professional describing the mitigation measures.

L. Non-conformities

a. The elimination of the nonconformities in a zoning district may be declared to be for a public purpose and wellbeing. Noncompliant illumination levels must be addressed and reduced to a level compliant with the regulations of this section. Nonconforming illumination levels must be addressed within one year from the time of the adoption of this section, except as authorized by the Zoning Board of Appeals.

###