

TOWN OF HALFMOON
CHAPTER 160
WATER RULES, REGULATIONS AND CONSTRUCTION STANDARDS

AMENDMENT SUMMARY

I. INTRODUCTION

- No changes.

II. APPLICATION FOR WATER SERVICE

- No changes.

III. SERVICES

- “Part A: Household (One and Two Family Residential)” Revised pipe material between corporation stop and curb valve to be CTS HDPE as opposed to Type K seamless copper tubing.

IV. LIMITING CONDITIONS AND RESTRICTIONS

- No changes.

V. CONSTRUCTION STANDARDS

- “Part K: Water Services” Revised Part 2 to include CTS HDPE as the Town standard.
- “Part L: Copper Water Service Pipe & Fittings” Revised section to include CTS HDPE as the Town standard. Copper service piping only to be used at the Town’s discretion.
- “Part M: HDPE Water Service Pipe” Revised section to include CTS HDPE as the Town standard.

VI. ADMINISTRATION

- No changes.

VII. WATER RATES, FEES & SCHEDULE

- No changes.

APPENDIX A – STANDARD WATER DETAILS

- Revised water service detail based on the construction standards updates (Section V)