

TO: Hamburg Township Board of Trustees

FROM: Tony Randazzo, Director of Technical & Utility Services

DATE: August, 12, 2026

AGENDA ITEM TOPIC: Valve Replacement at Hamburg Pump Station

Number of Supporting Documents: **02**

Requested Action

- Approve the quote from Comprehensive Contracting to replace the 8" gate valve and adjacent piping near the Hamburg Pump Station for a total cost of \$19,450.00.

Background

Last fall, when we had the issue with the deteriorated interior piping at the Hamburg Pump Station, we discovered that an 8" valve outside the station would not shut completely. Now, we'd like to replace the valve while the weather is good before it becomes a bigger problem.

We obtained a quote from a trusted contractor, Comprehensive Contracting, to perform the work. The estimate totals \$19,450, which is higher than initially expected due to the fusing and curing of the adjacent HDPE pipe that must take place. We also asked for a quote from our blanket contractor, C & E Construction. Unfortunately, they are too busy with other work right now and declined to bid.

Fiscal Considerations

Does the agenda item require the expenditure of funds? Yes ☒ No ☐

Are funds budgeted? Yes ☒ *draft No ☐

Fiscal year affected: 2026/2027

Is a budget amendment required? Yes ☐ No ☒

General Ledger numbers affected: 590.527.934.100

COMPREHENSIVE CONTRACTING

WORK ORDER

PO Box 2362
Brighton, MI 48116
Phone: [REDACTED] Email: [REDACTED]

DATE: 8/4/2026
PROJECT: Hamburg Station

Hamburg Township
P.O. BOX 157
Hamburg, MI. 48139
8" G.V. and F.M. Replacement

DESCRIPTION	QTY	RATE	AMOUNT
Remove and replace existing 8" valve			\$6,400.00
Remove and replace existing 45's with H.D.P.E.			\$4,100.00
Tie into existing H.D.P.E. line that terminates into station			\$3,500.00
Import sand for backfill and export spoils			\$1,500.00
8" valve, H.D.P.E. fittings and hardware			\$3,950.00
NOTE: Price does not include restorations of disturbed and excavated areas			
TOTAL			\$19,450.00



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

EXCERPT FROM HAMBURG TOWNSHIP MUNICIPAL UTILITIES COMMITTEE MEETING MINUTES

To the attention of: Jason B. Negri, Supervisor
Hamburg Township Board of Trustees

Re: **Hamburg Road Pump Station Valve Replacement**

Please be apprised of this excerpt from the ☒Unapproved ☐Approved Minutes of the Meeting
of the Hamburg Township Sewer Committee:

Date of Meeting: August 11th, 2026

Sewer Committee Members Present: Negri, Menzies, Daniels

Sewer Committee Members Absent: None


Text of Motion: MOTION BY MENZIES, SECONDED BY DANIELS TO FORWARD
THE REQUEST TO THE BOARD WITH THE RECOMMENDATION
TO APPROVE THE REPLACEMENT OF THE 8" VALVE AT THE
HAMBURG ROAD PUMP STATION AS REQUESTED.

Ayes: Negri, Menzies, Daniels Absent: None Nays: None

MOTION CARRIED.

State of Michigan }
County of Livingston }
Township of Hamburg }

I, BRITTANY K. CAMPBELL, Hamburg Township Utilities Coordinator and recording
secretary to the Municipal Utilities Committee, do hereby certify that the foregoing is a true and
correct excerpt of the Minutes of the aforementioned Regular/~~Special~~ Meeting of the Hamburg
Township Municipal Utilities Committee.

 Date: August 11th, 2026
BRITTANY K. CAMPBELL
HAMBURG TOWNSHIP UTILITIES COORDINATOR