



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

EXCERPT FROM HAMBURG TOWNSHIP MUNICIPAL UTILITIES COMMITTEE MEETING MINUTES

To the attention of: Jason B. Negri, Supervisor
Hamburg Township Board of Trustees

Re: **DPW Monthly Report – June 2026 Statistics**

Please be apprised of this excerpt from the ☒ Unapproved ☐ Approved Minutes of the Meeting of the Hamburg Township Sewer Committee:

Date of Meeting: July 14th, 2026

Sewer Committee Members Present: Negri, Menzies, Daniels

Sewer Committee Members Absent: None

Text of Motion: MOTION BY NEGRI, SECONDED BY MENZIES TO NOTE THE DPW MONTHLY REPORTS AS RECEIVED AND TO BE FILED AND TO ALSO FORWARD COPIES TO THE TOWNSHIP BOARD AS AN AGENDA ITEM FOR THEIR REVIEW.

Ayes: Negri, Menzies, Daniels Absent: None Nays: None

MOTION CARRIED.

State of Michigan }
County of Livingston }
Township of Hamburg }

I, BRITTANY K. CAMPBELL, Hamburg Township Utilities Coordinator and recording secretary to the Municipal Utilities Committee, do hereby certify that the foregoing is a true and correct excerpt of the Minutes of the aforementioned Regular/~~Special~~ Meeting of the Hamburg Township Municipal Utilities Committee.


BRITTANY K. CAMPBELL
HAMBURG TOWNSHIP UTILITIES COORDINATOR

Date: July 14th, 2026



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

To: Municipal Utilities Committee
From: Tony Randazzo
Date: 07-08-2026
Re: DPW Monthly Report

-
1. The daily testing at the wastewater treatment plant was in compliance for the month of June.
 2. EGLE has granted us a ninety-day extension of our PFAS grant. However, we are over 90% done with only a few tests left to complete.
 3. Our new full-time employee, Josh, started at the end of June.
 4. Our order for 100 grinder cores is expected to arrive July 13th which is timely, because we only have two cores left as of today.



Hamburg Township Monthly Field Report

June 2026

Ryan Ward

Grinder Calls: 58 Total / 22 OT

Plant Calls: 0 OT

Station Calls: 0 Hamburg/ 0 Portage

Pump Rebuilds: 45 Hamburg / 3 Portage / 1 Highland / 10 Scrapped

Miss Digs: 378 Hamburg / 50 Portage

Startups: 4

Deactivations/Reactivations: 0

Replacements: 0

Grinder Stations in Stock: 62 simplex / 2 duplex

Grinder Locations: 2

Grinder Pump Cores in Stock: 5 + 2 for Duplex

WWTP Average Influent Flow: 317138 Gallons

Field Jobs for the Month: This month we have completed our normal monthly checks, grease trap inspections and water meter readings. Our new full-time technician Josh Briggs started working 6/24. A new controller has been installed on the Kress station generator. At

Portage we had a new EONE duplex lift station installed for PS7. Freedom Rivers sewer pump station startup was completed with Kennedy Industries. The station is not receiving any flow at the moment.

