Hamburg Township
a great place to grow
10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

EXCERPT FROM HAMBURG TOWNSHIP MUNICIPAL UTILITIES COMMITTEE MEETING MINUTES

To the attention of: Jason B. Negri, Supervisor
Hamburg Township Board of Trustees

Re: **DPW Monthly Report – September 2026 Statistics**

Please be apprised of this excerpt from the [X]Unapproved [_]Approved Minutes of the Meeting of the Hamburg Township Sewer Committee:

Date of Meeting: October 13th, 2026

Sewer Committee Members Present: Negri, Menzies, Daniels

Sewer Committee Members Absent: None

Text of Motion: MOTION BY NEGRI, SECONDED BY MENZIES TO NOTE THE DPW MONTHLY REPORTS AS RECEIVED AND TO BE FILED AND TO ALSO FORWARD COPIES TO THE TOWNSHIP BOARD AS AN AGENDA ITEM FOR THEIR REVIEW.

Ayes: Negri, Menzies, Daniels Absent: None Nays: None

MOTION CARRIED.

State of Michigan }
County of Livingston }
Township of Hamburg}

I, BRITTANY K. CAMPBELL, Hamburg Township Utilities Coordinator and recording secretary to the Municipal Utilities Committee, do hereby certify that the foregoing is a true and correct excerpt of the Minutes of the aforementioned Regular/~~Special~~ Meeting of the Hamburg Township Municipal Utilities Committee.

Brittany K. Campbell Date: October 14th, 2026
BRITTANY K. CAMPBELL
HAMBURG TOWNSHIP UTILITIES COORDINATOR

Hamburg Township
a great place to grow
10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

To: Municipal Utilities Committee
From: Tony Randazzo
Date: 10-06-2026
Re: DPW Monthly Report

---

1. The daily testing at the wastewater treatment plant was in compliance for the month of September.

2. EGLE has given us another three-month extension for our PFAS grant to spend all remaining money on additional work.

3. Kennedy installed the new pump at the Hamburg PS just before Labor Day. The expedited shipping sped up delivery by roughly six weeks.

4. The severe storms that came through just before Labor Day weekend caused widespread power issues, most notably at the Ore Lake station where the generator failed. Repairs have since been made and we're back to normal operation.

Hamburg Township Monthly Field Report

September 2026

Ryan Ward

Grinder Calls: 63 Total / 32 OT

Plant Calls: 0 OT

Station Calls: 3 Hamburg/ 6 Portage (power outage)

Pump Rebuilds: 43 Hamburg / 0 Portage / 7 Highland / 5 Scrapped

Miss Digs: 243 Hamburg / 42 Portage

Startups: 1

Deactivations/Reactivations: 2

Replacements: 0

Grinder Stations in Stock: 53 simplex / 2 duplex

Grinder Locations: 0

Grinder Pump Cores in Stock: 80 + 2 for Duplex

WWTP Average Influent Flow: 306041 Gallons

Field Jobs for the Month: This month we have completed our normal monthly checks, water meter readings and grease trap inspections. We received a DelPac delivery for 2500 gallons on 9/24; the plant chemical pumps have been switched over to use DelPac until spring.

Total Energy Systems completed the routine inspections and maintenance for our listed generators this month. Comprehensive Contracting completed the Hamburg station gate valve replacement. Hamburg Township hosted a WWTP tour for the Huron River Chain of Lakes Association (HRCOLA) ON 9/19.



