Hamburg Township
a great place to grow
10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

EXCERPT FROM HAMBURG TOWNSHIP MUNICIPAL UTILITIES COMMITTEE MEETING MINUTES

To the attention of: Jason B. Negri, Supervisor
Hamburg Township Board of Trustees

Re: **DPW Monthly Report – August 2026 Statistics**

Please be apprised of this excerpt from the [X]Unapproved [_]Approved Minutes of the Meeting of the Hamburg Township Sewer Committee:

Date of Meeting: September 15th, 2026

Sewer Committee Members Present: Negri, Menzies, Daniels

Sewer Committee Members Absent: None

Text of Motion: MOTION BY NEGRI, SECONDED BY MENZIES TO NOTE THE DPW MONTHLY REPORTS AS RECEIVED AND TO BE FILED AND TO ALSO FORWARD COPIES TO THE TOWNSHIP BOARD AS AN AGENDA ITEM FOR THEIR REVIEW.

Ayes: Negri, Menzies, Daniels Absent: None Nays: None

MOTION CARRIED.

State of Michigan }
County of Livingston }
Township of Hamburg}

I, BRITTANY K. CAMPBELL, Hamburg Township Utilities Coordinator and recording secretary to the Municipal Utilities Committee, do hereby certify that the foregoing is a true and correct excerpt of the Minutes of the aforementioned Regular/~~Special~~ Meeting of the Hamburg Township Municipal Utilities Committee.

Brittany K. Campbell Date: September 15th, 2026
BRITTANY K. CAMPBELL
HAMBURG TOWNSHIP UTILITIES COORDINATOR

Hamburg Township
a great place to grow
10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

To: Municipal Utilities Committee
From: Tony Randazzo
Date: 09-02-2026
Re: DPW Monthly Report

---

1. The daily testing at the wastewater treatment plant was in compliance for the month of August.

2. All PFAS testing work for the grant is complete, now working on the final report due at the end of the month

3. Ryan has been working with a 3D printing company to produce a bracket that is no longer made for our older grinder pumps. The prototype looks very promising.

4. Now that we are back at full staffing levels, we have resumed data collection of our sewer infrastructure.

Hamburg Township Monthly Field Report

August 2026

Ryan Ward

Grinder Calls: 53 Total / 24 OT

Plant Calls: 0 OT

Station Calls: 3 Hamburg/ 0 Portage

Pump Rebuilds: 40 Hamburg / 1 Portage / 4 Highland / 8 Scrapped

Miss Digs: 239 Hamburg / 40 Portage

Startups: 1

Deactivations/Reactivations: 2

Replacements: 1

Grinder Stations in Stock: 56 simplex / 2 duplex

Grinder Locations: 1

Grinder Pump Cores in Stock: 84 + 2 for Duplex

WWTP Average Influent Flow: 315605 Gallons

Field Jobs for the Month: This month we have completed our normal monthly checks and Hamburg/Portage monitoring well sampling. We sampled Hamburg Hardware for a PFAS drinking water test. Biotech has completed a haul applying roughly 603,000 gallons of sludge to a

field in Gregory. We did have one sanitary sewer break at 5635 Trailside ln; there was a split at an abandoned sewer tap that was not on our sewer prints. This was dug up and repaired by Comprehensive Contracting.



