



10405 Merrill Road ♦ P.O. Box 157  
Hamburg, MI 48139  
Phone: 810.231.1000 ♦ Fax: 810.231.4295  
www.hamburg.mi.us

## EXCERPT FROM HAMBURG TOWNSHIP MUNICIPAL UTILITIES COMMITTEE MEETING MINUTES

To the attention of: Patrick J. Hohl, Supervisor  
Hamburg Township Board of Trustees

Re: **DPW Monthly Report – May 2025 Statistics**

Please be apprised of this excerpt from the ☒Unapproved ☐Approved Minutes of the Meeting  
of the Hamburg Township Sewer Committee:

Date of Meeting: June 10<sup>th</sup>, 2025

Sewer Committee Members Present: Hohl, Menzies, Negri

Sewer Committee Members Absent: None


Text of Motion: MOTION BY HOHL, SECONDED BY MENZIES TO NOTE THE  
DPW MONTHLY REPORT AS RECEIVED AND TO BE FILED AND  
TO ALSO FORWARD A COPY TO THE TOWNSHIP BOARD AS AN  
AGENDA ITEM FOR THEIR REVIEW.

Ayes: Hohl, Menzies, Negri Absent: None Nays: None

MOTION CARRIED.

State of Michigan }  
County of Livingston }  
Township of Hamburg }

I, BRITTANY K. CAMPBELL, Hamburg Township Utilities Coordinator and recording  
secretary to the Municipal Utilities Committee, do hereby certify that the foregoing is a true and  
correct excerpt of the Minutes of the aforementioned Regular/~~Special~~ Meeting of the Hamburg  
Township Municipal Utilities Committee.

 Date: June 10<sup>th</sup>, 2025  
BRITTANY K. CAMPBELL  
HAMBURG TOWNSHIP UTILITIES COORDINATOR



10405 Merrill Road ♦ P.O. Box 157  
Hamburg, MI 48139  
Phone: 810.231.1000 ♦ Fax: 810.231.4295  
[www.hamburg.mi.us](http://www.hamburg.mi.us)

To: Municipal Utilities Committee  
From: Tony Randazzo  
Date: 06-04-2025  
Re: DPW Monthly Report

- 
1. The wastewater treatment plant was in compliance for May.
  2. The odor control system has continued to work well at the Kress Rd. pump station. Work is nearly complete on installing a similar system at the Rustic Dr. pump station. We're just waiting on the blower fan.
  3. We sampled three pump stations for PFAS as part of the grant work. Three additional ones were just sampled earlier this week. Four new monitoring wells are being installed this week as well.



## **Hamburg Township Monthly Field Report**

**May 2025**

**Ryan Ward**

**Grinder Calls: 41 Total / 18 OT**

**Plant Calls: 0 OT**

**Station Calls: 0 Hamburg/ 0 Portage**

**Pump Rebuilds: 26 Hamburg / 0 Portage / 0 Highland**

**Miss Digs: 242 Hamburg / 46 Portage**

**Startups: 2**

**Deactivations/Reactivations: 0**

**Replacements: 0**

**Grinder Stations in Stock: 35 simplex / 2 duplex**

**Grinder Locations: 1**

**Grinder Pump Cores in Stock: 15 + 2 for Duplex**

**Field Jobs for the Month:** This month we have completed our normal monthly checks along with the quarterly monitoring well sampling. The WWTP had a new radar level sensor installed in the EQ basin to help report more accurate levels and upgrade our deteriorating stick level transmitter. The plant Muffin Monster used for grinding and



pureeing debris material in the influent is past its life expectancy and is being quoted to replace the cutter teeth or replace the entire unit. The WWTP received a load of 2500 gallons of Alum chemical. Our staff has started the Rustic station odor control bed construction; the project is about halfway done. We have some more piping to work on, spreading mulch and the blower to get installed.

