



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

EXCERPT FROM HAMBURG TOWNSHIP MUNICIPAL UTILITIES COMMITTEE MEETING MINUTES

To the attention of: Jason B. Negri, Supervisor
Hamburg Township Board of Trustees

Re: **DPW Monthly Report – July 2026 Statistics**

Please be apprised of this excerpt from the ☒Unapproved ☐Approved Minutes of the Meeting
of the Hamburg Township Sewer Committee:

Date of Meeting: August 11th, 2026

Sewer Committee Members Present: Negri, Menzies, Daniels

Sewer Committee Members Absent: None

Text of Motion: MOTION BY NEGRI, SECONDED BY DANIELS TO NOTE THE
DPW MONTHLY REPORTS AS RECEIVED AND TO BE FILED AND
TO ALSO FORWARD COPIES TO THE TOWNSHIP BOARD AS AN
AGENDA ITEM FOR THEIR REVIEW.

Ayes: Negri, Menzies, Daniels Absent: None Nays: None

MOTION CARRIED.

State of Michigan }
County of Livingston }
Township of Hamburg }

I, BRITTANY K. CAMPBELL, Hamburg Township Utilities Coordinator and recording
secretary to the Municipal Utilities Committee, do hereby certify that the foregoing is a true and
correct excerpt of the Minutes of the aforementioned Regular/~~Special~~ Meeting of the Hamburg
Township Municipal Utilities Committee.


BRITTANY K. CAMPBELL
HAMBURG TOWNSHIP UTILITIES COORDINATOR

Date: August 11th, 2026,



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

To: Municipal Utilities Committee
From: Tony Randazzo
Date: 08-05-2026
Re: DPW Monthly Report

-
1. The daily testing at the wastewater treatment plant was in compliance for the month of July.
 2. We are finishing up our PFAS testing as part of the grant work. The final samples will be taken next week. I will then work on the final report later this month.
 3. Glen has returned to work this week, so we are back to being fully staffed.
 4. A pump has failed at the Hamburg Rd. Pump Station, but it's cost prohibitive to repair given its age and the parts required, not to mention the lead time. A new one has been ordered and will take up to sixteen weeks to arrive.



Hamburg Township Monthly Field Report

July 2026

Ryan Ward

Grinder Calls: 63 Total / 28 OT

Plant Calls: 0 OT

Station Calls: 0 Hamburg/ 0 Portage

Pump Rebuilds: 40 Hamburg / 1 Portage / 4 Highland / 8 Scrapped

Miss Digs: 218 Hamburg / 30 Portage

Startups: 1

Deactivations/Reactivations: 1

Replacements: 0

Grinder Stations in Stock: 59 simplex / 2 duplex

Grinder Locations: 0

Grinder Pump Cores in Stock: 90 + 2 for Duplex

WWTP Average Influent Flow: 331863 Gallons

Field Jobs for the Month: This month we have completed our normal monthly checks. The WWTP received a 2500 gallon load of Alum chemical, this should last us a couple months until we need to switch to DelPac. We received our 100 EONE Extreme pump delivery, all

were able to be stored in the pump barn with the help of a pallet jack. The Hamburg station odor bed is now on and complete, this will help eliminate odors outside of the station and inside of the wiring.

