



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

EXCERPT FROM HAMBURG TOWNSHIP MUNICIPAL UTILITIES COMMITTEE MEETING MINUTES

To the attention of: Jason B. Negri, Supervisor
Hamburg Township Board of Trustees

Re: **DPW Monthly Report – April 2026 Statistics**

Please be apprised of this excerpt from the Unapproved Approved Minutes of the Meeting of the Hamburg Township Sewer Committee:

Date of Meeting: May 12th, 2026

Sewer Committee Members Present: Negri, Menzies, Daniels

Sewer Committee Members Absent: None


Text of Motion: MOTION BY NEGRI, SECONDED BY MENZIES TO NOTE THE DPW MONTHLY REPORTS AS RECEIVED AND TO BE FILED AND TO ALSO FORWARD COPIES TO THE TOWNSHIP BOARD AS AN AGENDA ITEM FOR THEIR REVIEW.

Ayes: Negri, Menzies, Daniels Absent: None Nays: None

MOTION CARRIED.

State of Michigan }
County of Livingston }
Township of Hamburg }

I, BRITTANY K. CAMPBELL, Hamburg Township Utilities Coordinator and recording secretary to the Municipal Utilities Committee, do hereby certify that the foregoing is a true and correct excerpt of the Minutes of the aforementioned Regular/~~Special~~ Meeting of the Hamburg Township Municipal Utilities Committee.

 Date: May 12th, 2026
BRITTANY K. CAMPBELL
HAMBURG TOWNSHIP UTILITIES COORDINATOR



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

To: Municipal Utilities Committee
From: Tony Randazzo
Date: 05-07-2026
Re: DPW Monthly Report

-
1. The daily testing at the wastewater treatment plant was in compliance for the month of April.
 2. The City of Brighton had a contractor investigate the new water meter that records flow from our sewer system into their WWTP plant. Unfortunately, they found that the new meter is reading correctly, which means we will incur higher quarterly charges amounting to approximately an extra \$50,000 per year.
 3. Biotech performed the spring sludge haul. They took 90% of the sludge so we'll be in good shape until at least mid-July.
 4. Our shipment of new grinder pumps will arrive next week.



Hamburg Township Monthly Field Report

April 2026

Ryan Ward

Grinder Calls: 28 Total / 7 OT

Plant Calls: 0 OT

Station Calls: 0 Hamburg/ 0 Portage

**Pump Rebuilds: 18 Hamburg / 4 Portage / 4 Highland / 1 Brighton /
7 Scrapped**

Miss Digs: 257 Hamburg / 41 Portage

Startups: 2

Deactivations/Reactivations: 0

Replacements: 0

Grinder Stations in Stock: 10 simplex / 2 duplex

Grinder Locations: 2

Grinder Pump Cores in Stock: 15 + 2 for Duplex

WWTP Average Influent Flow: 306964 Gallons

Field Jobs for the Month: This month we have completed our normal monthly checks. Grinder calls were at a low this month, which allowed us to complete other tasks for Portage Base and Hamburg.

Our staff started the Hamburg station odor control bed project. We received our Alum chemical delivery this month and switched to using Alum instead of DelPac for the warmer seasons. Our staff attended an electrical training class held by Darick from Kerr pump at our facility and a confined space training class at our facility. Biotech has finished 90% of the haul.

