



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

EXCERPT FROM HAMBURG TOWNSHIP MUNICIPAL UTILITIES COMMITTEE MEETING MINUTES

To the attention of: Jason B. Negri, Supervisor
Hamburg Township Board of Trustees

Re: **DPW Monthly Report – February/March 2026 Statistics**

Please be apprised of this excerpt from the Unapproved Approved Minutes of the Meeting of the Hamburg Township Sewer Committee:

Date of Meeting: April 14th, 2026

Sewer Committee Members Present: Negri, Daniels

Sewer Committee Members Absent: Menzies


Text of Motion: MOTION BY DANIELS, SECONDED BY NEGRI TO NOTE THE DPW MONTHLY REPORTS AS RECEIVED AND TO BE FILED AND TO ALSO FORWARD COPIES TO THE TOWNSHIP BOARD AS AN AGENDA ITEM FOR THEIR REVIEW.

Ayes: Negri, Daniels Absent: Menzies Nays: None

MOTION CARRIED.

State of Michigan }
County of Livingston }
Township of Hamburg }

I, BRITTANY K. CAMPBELL, Hamburg Township Utilities Coordinator and recording secretary to the Municipal Utilities Committee, do hereby certify that the foregoing is a true and correct excerpt of the Minutes of the aforementioned Regular/~~Special~~ Meeting of the Hamburg Township Municipal Utilities Committee.

 Date: April 15th, 2026
BRITTANY K. CAMPBELL
HAMBURG TOWNSHIP UTILITIES COORDINATOR



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

To: Municipal Utilities Committee
From: Tony Randazzo
Date: 04-09-2026
Re: DPW Monthly Report

-
1. The daily testing at the wastewater treatment plant was in compliance for the month of March.
 2. We're preparing to install a mulch bed at the Hamburg Rd. pump station for odor control. Most of the materials are already here, including the blower fan. We also had to fill out a permit with MDOT to use additional land at the station.
 3. We received an abnormally high bill from the City of Brighton last week for the sewage we send to their plant. After investigating our own collection system and not finding anything out of the ordinary, we contacted Brighton's DPW and they found that the new water meter they installed to monitor our usage appears to be showing higher usage than is actually occurring. They have a contractor scheduled to remediate the problem.



Hamburg Township Monthly Field Report

March 2026

Ryan Ward

Grinder Calls: 40 Total / 21 OT

Plant Calls: 0 OT

Station Calls: 0 Hamburg/ 0 Portage

Pump Rebuilds: 28 Hamburg / 0 Portage / 0 Highland / 1 Scrapped

Miss Digs: 147 Hamburg / 36 Portage

Startups: 1

Deactivations/Reactivations: 0

Replacements: 0

Grinder Stations in Stock: 13 simplex / 2 duplex

Grinder Locations: 0

Grinder Pump Cores in Stock: 16 + 2 for Duplex

WWTP Average Influent Flow: 289054 Gallons

Field Jobs for the Month: This month we have completed our normal monthly checks along with water meter readings and grease trap inspections. Total Energy Systems has completed the PM on our 6

standby generators. Our staff has been making good steady progress on the manhole project.





10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

To: Municipal Utilities Committee
From: Tony Randazzo
Date: 03-05-2026
Re: DPW Monthly Report

-
1. The daily testing at the wastewater treatment plant was in compliance for the month of February.
 2. We received our quarterly reimbursement for the PFAS grant. I had a meeting with EGLE about our grant work. Based upon the results so far, they want us to test an additional eleven homes. Fortunately, we have enough money left in the grant to cover this additional cost. We'll plan on testing these homes in April or May when the weather warms up.
 3. DPW has obtained a 2011 F-350 from the Fire Department to use for daily operations. The truck has relatively low mileage and has been well maintained. DPW will share this truck with Buildings and Grounds in the warmer months to balance the needs of both departments.



Hamburg Township Monthly Field Report

February 2026

Ryan Ward

Grinder Calls: 57 Total / 32 OT

Plant Calls: 0 OT

Station Calls: 0 Hamburg/ 0 Portage

Pump Rebuilds: 24 Hamburg / 0 Portage / 9 Highland / 5 Scrapped

Miss Digs: 85 Hamburg / 13 Portage

Startups: 0

Deactivations/Reactivations: 0

Replacements: 0

Grinder Stations in Stock: 15 simplex / 2 duplex

Grinder Locations: 1

Grinder Pump Cores in Stock: 19 + 2 for Duplex

WWTP Average Influent Flow: 297007 Gallons

Field Jobs for the Month: This month we have completed our normal monthly checks along with monitoring well sampling. Hamburg, Medical Center, and Chilson Commons stations have been sampled for PFAS, we are waiting for results from Merit Laboratories. Winans

station piping has been replaced with HDPE piping with the assistance of C&E Construction. The station is back to normal. This month we received a DelPac chemical delivery.

