



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

EXCERPT FROM HAMBURG TOWNSHIP MUNICIPAL UTILITIES COMMITTEE MEETING MINUTES

To the attention of: Patrick J. Hohl, Supervisor
Hamburg Township Board of Trustees

Re: **DPW Monthly Report – September 2022 Statistics**

Please be apprised of this excerpt from the ☒ Unapproved ☐ Approved Minutes of the Meeting
of the Hamburg Township Sewer Committee:

Date of Meeting: October 12th, 2022

Sewer Committee Members Present: Hohl, Hahn, Michniewicz

Sewer Committee Members Absent: None

Text of Motion: MOTION BY HOHL, SUPPORTED BY HAHN TO NOTE THE DPW
MONTHLY REPORT AS RECEIVED AND TO BE FILED AND TO
ALSO FORWARD A COPY TO THE TOWNSHIP BOARD AS AN
AGENDA ITEM FOR THEIR REVIEW.

Ayes: Hohl, Hahn, Michniewicz Absent: None Nays: None

MOTION CARRIED.

State of Michigan }
County of Livingston }
Township of Hamburg }

I, BRITTANY K. CAMPBELL, Hamburg Township Utilities Coordinator and recording
secretary to the Municipal Utilities Committee, do hereby certify that the foregoing is a true and
correct excerpt of the Minutes of the aforementioned Regular/~~Special~~ Meeting of the Hamburg
Township Municipal Utilities Committee.


BRITTANY K. CAMPBELL
HAMBURG TOWNSHIP UTILITIES COORDINATOR

Date: October 12th, 2022



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

To: Municipal Utilities Committee
From: Tony Randazzo
Date: 10-04-2022
Re: DPW Monthly Report

-
1. The wastewater treatment plant was in compliance for the month of September.
 2. C&E Construction has started the sewer extension project along M-36 between Pettysville Rd. and Country Elementary.
 3. A representative from EGLE has requested a meeting with us to discuss PFAS contamination. We're in the process of scheduling said meeting.
 4. We received our large grinder pump order two months earlier than quoted.



Hamburg Township Monthly Field Report

September 2022

Ryan Ward

Grinder Calls: 57 Total / 25 OT

Plant Calls: 3 OT

Station Calls: 0

Pump Rebuilds: 40 Hamburg / 0 Portage / 2 Highland

Miss Digs: 224 Hamburg / 41 Portage

Startups: 2

Deactivations/Reactivations: 0

Replacements: 1

Field Jobs for the Month: This month we have completed our normal monthly checks along with water meter readings and grease trap inspections. We had a main break on Winans Lake rd this month leading to us put in 16 hours of work in two days and shutting down all of Winans dr to make a repair. The staff rerouted the 6in line from Petty's road into the 8in force main that comes to the plant, this helps with the age of the sewer. This rerouted roughly 25,000 gallons of sewage to go straight to the plant instead of going to Kress station then to the plant. Over a year ago we had found an issue with the

plant decant flanges, the bolts were so corroded it created a gap in the flanges allowing unwanted solids to enter the decant pipe. The staff replaced the bolts for both tanks this month with stainless steel bolts to ensure it doesn't happen again for a long time. We received our delivery from EONE for 118 grinder pump stations.

