



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

EXCERPT FROM HAMBURG TOWNSHIP MUNICIPAL UTILITIES COMMITTEE MEETING MINUTES

To the attention of: Patrick J. Hohl, Supervisor
Hamburg Township Board of Trustees

Re: **DPW Monthly Report – February 2023 Statistics**

Please be apprised of this excerpt from the Unapproved Approved Minutes of the Meeting of the Hamburg Township Sewer Committee:

Date of Meeting: March 8th, 2023

Sewer Committee Members Present: Hohl, Michniewicz

Sewer Committee Members Absent: None


Text of Motion: MOTION BY HOHL, SUPPORTED BY MICHNIEWICZ TO NOTE THE DPW MONTHLY REPORT AS RECEIVED AND TO BE FILED AND TO ALSO FORWARD A COPY TO THE TOWNSHIP BOARD AS AN AGENDA ITEM FOR THEIR REVIEW.

Ayes: Hohl, Michniewicz Absent: Hahn Nays: None

MOTION CARRIED.

State of Michigan }
County of Livingston }
Township of Hamburg }

I, BRITTANY K. CAMPBELL, Hamburg Township Utilities Coordinator and recording secretary to the Municipal Utilities Committee, do hereby certify that the foregoing is a true and correct excerpt of the Minutes of the aforementioned Regular/~~Special~~ Meeting of the Hamburg Township Municipal Utilities Committee.

 Date: March 8th, 2023
BRITTANY K. CAMPBELL
HAMBURG TOWNSHIP UTILITIES COORDINATOR



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

To: Municipal Utilities Committee
From: Tony Randazzo
Date: 03-02-2023
Re: DPW Monthly Report

-
1. The wastewater treatment plant was out of compliance for one day in February for total inorganic nitrogen.
 2. At EGLE's request, we sampled monitoring well #12 for PFAS and the results came back as non-detect. We still have not been able to obtain water samples for PFAS testing from any of the four homes near Buck Lake due to a lack of response from the homeowners.
 3. We had a virtual meeting with EGLE on 2/6 to discuss the next steps regarding PFAS at our wastewater treatment plant. At the meeting, our wastewater treatment plant was officially listed as an MPART site for PFAS. Moving forward, EGLE wants to see some additional testing results before anything else is done.



Hamburg Township Monthly Field Report

February 2023

Ryan Ward

Grinder Calls: 29 Total / 12 OT

Plant Calls: 0 OT

Station Calls: 0

Pump Rebuilds: 27 Hamburg / 2 Portage / 1 Highland

Miss Digs: 90 Hamburg / 16 Portage

Startups: 1

Deactivations/Reactivations: 0

Replacements: 2

Field Jobs for the Month: This month we have completed our normal monthly checks along with the monitoring well sampling. The staff have started working on the manhole project in the Gallagher Blvd area. Brighton Wastewater brought over their camera trailer to visually see what is going on with some piping on Industrial Road, we found a belly in the gravity line that extends roughly 40ft out from MH-7. This belly is causing most of the solids and debris to settle and create a partial clog. We found this issue 2 weeks after Metro Industries had jetted our lines. Midwest Power Systems started on

replacing the discharge piping for Ore Station, we are now having issues with one of our key bypass valves to complete this work. A new valve will be installed by Watertap to finish this project and ensure we have a complete bypass for any future emergencies.

