



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

EXCERPT FROM HAMBURG TOWNSHIP MUNICIPAL UTILITIES COMMITTEE MEETING MINUTES

To the attention of: Patrick J. Hohl, Supervisor
Hamburg Township Board of Trustees

Re: **DPW Monthly Report – February 2024 Statistics**

Please be apprised of this excerpt from the Unapproved Approved Minutes of the Meeting of the Hamburg Township Sewer Committee:

Date of Meeting: March 13th, 2024

Sewer Committee Members Present: Hohl, Michniewicz

Sewer Committee Members Absent: Hahn


Text of Motion: MOTION BY HOHL, SUPPORTED BY MICHNIEWICZ TO NOTE THE DPW MONTHLY REPORT AS RECEIVED AND TO BE FILED AND TO ALSO FORWARD A COPY TO THE TOWNSHIP BOARD AS AN AGENDA ITEM FOR THEIR REVIEW.

Ayes: Hohl, Michniewicz Absent: Hahn Nays: None

MOTION CARRIED.

State of Michigan }
County of Livingston }
Township of Hamburg }

I, BRITTANY K. CAMPBELL, Hamburg Township Utilities Coordinator and recording secretary to the Municipal Utilities Committee, do hereby certify that the foregoing is a true and correct excerpt of the Minutes of the aforementioned Regular/~~Special~~ Meeting of the Hamburg Township Municipal Utilities Committee.


Date: March 14th, 2024
BRITTANY K. CAMPBELL
HAMBURG TOWNSHIP UTILITIES COORDINATOR



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

To: Municipal Utilities Committee
From: Tony Randazzo
Date: 03-06-2024
Re: DPW Monthly Report

-
1. The wastewater treatment plant was in compliance for the month of February.
 2. We submitted our grant application to EGLE for PFAS testing last month. The grant monies will be awarded in June.
 3. Ryan, Jon, and I met with our engineer, Ted Erickson to discuss preliminary design for an expansion of our wastewater treatment plant in the future. Although this project is still a number of years away, we want to have a rough idea of the cost involved and not have to start from square one when the time comes.



Hamburg Township Monthly Field Report

February 2024

Ryan Ward

Grinder Calls: 35 Total / 12 OT

Plant Calls: 0 OT

Station Calls: 1 Hamburg/ 1 Portage

Pump Rebuilds: 35 Hamburg / 2 Portage / 1 Highland

Miss Digs: 120 Hamburg / 16 Portage

Startups: 1

Deactivations/Reactivations: 0

Replacements: 8

Grinder Stations in Stock: 54 simplex / 1 duplex

Grinder Locations: 1

Grinder Pump Cores in Stock: 40 + 2 for Duplex

Field Jobs for the Month: This month we have completed our normal monthly checks along with the monitoring well sampling. This month C&E Construction has been working hard on the replacement list, they were wrapping up with the old list, so we created a new list of 23 homes to continue working on. Biotech completed the sludge haul at the

beginning of the month. Pump 1 at Kress station was tripping the station due to poor field service from Kennedy industries. The main wires were not wrapped properly causing them to prematurely wear and create arcing issues. The staff has been working on the manhole project when time allows on Bob White Beach Blvd.

