



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

EXCERPT FROM HAMBURG TOWNSHIP MUNICIPAL UTILITIES COMMITTEE MEETING MINUTES

To the attention of: Jason B. Negri, Supervisor
Hamburg Township Board of Trustees

Re: **DPW Monthly Report – September 2025 Statistics**

Please be apprised of this excerpt from the Unapproved Approved Minutes of the Meeting of the Hamburg Township Sewer Committee:

Date of Meeting: October 14th, 2025

Sewer Committee Members Present: Menzies, Daniels

Sewer Committee Members Absent: Negri


Text of Motion: MOTION BY DANIELS, SECONDED BY MENZIES TO NOTE THE DPW MONTHLY REPORT AS RECEIVED AND TO BE FILED AND TO ALSO FORWARD A COPY TO THE TOWNSHIP BOARD AS AN AGENDA ITEM FOR THEIR REVIEW.

Ayes: Menzies, Daniels Absent: Negri Nays: None

MOTION CARRIED.

State of Michigan }
County of Livingston }
Township of Hamburg }

I, BRITTANY K. CAMPBELL, Hamburg Township Utilities Coordinator and recording secretary to the Municipal Utilities Committee, do hereby certify that the foregoing is a true and correct excerpt of the Minutes of the aforementioned Regular/~~Special~~ Meeting of the Hamburg Township Municipal Utilities Committee.

 Date: October 14th, 2025
BRITTANY K. CAMPBELL
HAMBURG TOWNSHIP UTILITIES COORDINATOR



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

To: Municipal Utilities Committee
From: Tony Randazzo
Date: 10-08-2025
Re: DPW Monthly Report

-
1. The daily testing for the wastewater treatment plant was out of compliance for one day in September for phosphorus and one day for total inorganic nitrogen. A failed DO probe on a weekend caused the issue.
 2. The blower fan for the Rustic Station odor control system was installed, and the system was activated. We did, however, receive some noise complaints about the fan so our staff is in the process of building an enclosure to dampen the sound.
 3. Merit Laboratories has sampled 12 homes for PFAS in the Buck Lake area as part of our grant work. Eight of the samples have been non-detect for all PFAS, while four have shown small amounts that are below the maximum limit.
 4. As I discussed at the Board meeting the other day, E-One recently informed us that they will no longer manufacture parts for the 2000 series grinder pumps. Our immediate plan is to buy a large quantity of existing parts from E-One, which will then give us time to evaluate substitute parts from a different supplier to see if the quality meets expectations.



Hamburg Township Monthly Field Report

September 2025

Ryan Ward

Grinder Calls: 51 Total / 10 OT

Plant Calls: 1 OT

Station Calls: 0 Hamburg/ 0 Portage

Pump Rebuilds: 29 Hamburg / 3 Portage / 3 Highland / 4 Scrapped

Miss Digs: 244 Hamburg / 40 Portage

Startups: 2

Deactivations/Reactivations: 1

Replacements: 1

Grinder Stations in Stock: 18 simplex / 1 duplex

Grinder Locations: 0

Grinder Pump Cores in Stock: 11 + 2 for Duplex

Field Jobs for the Month: This month we have completed our normal monthly checks along with the water meter readings and grease trap inspections. We have had multiple Portage jobs this month consuming some of our time (aerators, station issues, station discharge repairs, new panel). The Rustic odor control blower is up and running with the

water timer on. We received a couple noise complaints from neighboring homes about the noise from the new odor control blower, we are working on a solution to try and mitigate these issues. Freedom River has continued progress inside and outside of the station.

