



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

EXCERPT FROM HAMBURG TOWNSHIP MUNICIPAL UTILITIES COMMITTEE MEETING MINUTES

To the attention of: Patrick J. Hohl, Supervisor
Hamburg Township Board of Trustees

Re: **DPW Monthly Report – September 2023 Statistics**

Please be apprised of this excerpt from the ☒Unapproved ☐Approved Minutes of the Meeting
of the Hamburg Township Sewer Committee:

Date of Meeting: October 11th, 2023

Sewer Committee Members Present: Hohl, Hahn

Sewer Committee Members Absent: Michniewicz


Text of Motion: MOTION BY HOHL, SUPPORTED BY HAHN TO NOTE THE DPW
MONTHLY REPORT AS RECEIVED AND TO BE FILED AND TO
ALSO FORWARD A COPY TO THE TOWNSHIP BOARD AS AN
AGENDA ITEM FOR THEIR REVIEW.

Ayes: Hohl, Hahn Absent: Michniewicz Nays: None

MOTION CARRIED.

State of Michigan }
County of Livingston }
Township of Hamburg }

I, BRITTANY K. CAMPBELL, Hamburg Township Utilities Coordinator and recording
secretary to the Municipal Utilities Committee, do hereby certify that the foregoing is a true and
correct excerpt of the Minutes of the aforementioned Regular/~~Special~~ Meeting of the Hamburg
Township Municipal Utilities Committee.


BRITTANY K. CAMPBELL
HAMBURG TOWNSHIP UTILITIES COORDINATOR

Date: October 11th, 2023



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

To: Municipal Utilities Committee
From: Tony Randazzo
Date: 10-04-2023
Re: DPW Monthly Report

-
1. The wastewater treatment plant was in compliance for the entire month of September.
 2. The process piping was replaced at the Rustic pump station because of degradation to the pipes caused by hydrogen sulfide gas. As with the other stations, we used stainless steel pipe this time for better longevity.
 3. Biotech completed the fall sludge haul.
 4. We're still planning on having the new heat exchanger and boiler installed for this winter. The contractor has indicated a delay with the unit but is working on having it shipped earlier.



Hamburg Township Monthly Field Report

September 2023

Ryan Ward

Grinder Calls: 52 Total / 23 OT

Plant Calls: 0 OT

Station Calls: 1

Pump Rebuilds: 33 Hamburg / 3 Portage / 14 Highland

Miss Digs: 187 Hamburg / 43 Portage

Startups: 0

Deactivations/Reactivations: 0

Replacements: 9

Grinder Stations in Stock: 91

Grinder Locations: 2

Grinder Pump Cores in Stock: 31

Field Jobs for the Month: This month we have completed our normal monthly checks along with the water meter readings and grease trap inspections. Biotech has completed a sludge haul this month; they got all the tanks emptied in one week. C&E Construction has completed 9 replacements this month and continues to pick up/schedule more jobs

to be done. Midwest Power Systems replaced the piping at Rustic station with new stainless-steel piping that will hold up better to the bad environment in the lift stations.

