



10405 Merrill Road ♦ P.O. Box 157  
Hamburg, MI 48139  
Phone: 810.231.1000 ♦ Fax: 810.231.4295  
www.hamburg.mi.us

## EXCERPT FROM HAMBURG TOWNSHIP MUNICIPAL UTILITIES COMMITTEE MEETING MINUTES

To the attention of: Patrick J. Hohl, Supervisor  
Hamburg Township Board of Trustees

Re: **DPW Monthly Report – February 2025 Statistics**

Please be apprised of this excerpt from the ☒Unapproved ☐Approved Minutes of the Meeting  
of the Hamburg Township Sewer Committee:

Date of Meeting: March 11<sup>th</sup>, 2025

Sewer Committee Members Present: Hohl, Negri

Sewer Committee Members Absent: Menzies


Text of Motion: MOTION BY NEGRI, SECONDED BY HOHL TO NOTE THE DPW  
MONTHLY REPORT AS RECEIVED AND TO BE FILED AND TO  
ALSO FORWARD A COPY TO THE TOWNSHIP BOARD AS AN  
AGENDA ITEM FOR THEIR REVIEW.

Ayes: Hohl, Negri Absent: Menzies Nays: None

MOTION CARRIED.

State of Michigan }  
County of Livingston }  
Township of Hamburg }

I, BRITTANY K. CAMPBELL, Hamburg Township Utilities Coordinator and recording  
secretary to the Municipal Utilities Committee, do hereby certify that the foregoing is a true and  
correct excerpt of the Minutes of the aforementioned Regular/~~Special~~ Meeting of the Hamburg  
Township Municipal Utilities Committee.

  
BRITTANY K. CAMPBELL  
HAMBURG TOWNSHIP UTILITIES COORDINATOR

Date: March 11<sup>th</sup>, 2025



10405 Merrill Road ♦ P.O. Box 157  
Hamburg, MI 48139  
Phone: 810.231.1000 ♦ Fax: 810.231.4295  
[www.hamburg.mi.us](http://www.hamburg.mi.us)

To: Municipal Utilities Committee  
From: Tony Randazzo  
Date: 03-06-2025  
Re: DPW Monthly Report

- 
1. The wastewater treatment plant was in compliance for February.
  2. With the recent warm weather, we have turned back on the blower fan at the Kress Rd. pump station to re-activate the odor control bed. We will continue to monitor the situation but have seen some positive signs of biological activity.
  3. C&E has continued to make good progress with the grinder replacement program, completing nine replacements in the month of February. We now have less than forty to go.



## **Hamburg Township Monthly Field Report**

**February 2025**

**Ryan Ward**

**Grinder Calls: 59 Total / 23 OT**

**Plant Calls: 1 OT**

**Station Calls: 0 Hamburg/ 0 Portage**

**Pump Rebuilds: 36 Hamburg / 2 Portage / 4 Highland**

**Miss Digs: 53 Hamburg / 19 Portage**

**Startups: 1**

**Deactivations/Reactivations: 0**

**Replacements: 8**

**Grinder Stations in Stock: 46 simplex / 2 duplex**

**Grinder Locations: 0**

**Grinder Pump Cores in Stock: 15 + 2 for Duplex**

**Field Jobs for the Month:** This month we have completed our normal monthly checks along with the monitoring well sampling. C&E Construction has replaced eight (8) 200 series grinder pump stations. We have been receiving some extreme cores back from these installs to help inventory, the staff has also been digging through the Highland

**Treatment 2000 series scrap pumps which has allowed us to recover 5 2000 series pumps for our inventory.**

**The plant received an order of 2500 gallons of DelPac on 2/20.**

