



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

EXCERPT FROM HAMBURG TOWNSHIP MUNICIPAL UTILITIES COMMITTEE MEETING MINUTES

To the attention of: Patrick J. Hohl, Supervisor
Hamburg Township Board of Trustees

Re: **DPW Monthly Report – May 2024 Statistics**

Please be apprised of this excerpt from the ☒ Unapproved ☐ Approved Minutes of the Meeting
of the Hamburg Township Sewer Committee:

Date of Meeting: July 10th, 2024

Sewer Committee Members Present: Hahn, Michniewicz

Sewer Committee Members Absent: Hohl


Text of Motion: MOTION BY HAHN, SUPPORTED BY MICHNIEWICZ TO NOTE
THE DPW MONTHLY REPORT AS RECEIVED AND TO BE FILED
AND TO ALSO FORWARD A COPY TO THE TOWNSHIP BOARD AS
AN AGENDA ITEM FOR THEIR REVIEW.

Ayes: Hahn, Michniewicz Absent: Hohl Nays: None

MOTION CARRIED.

State of Michigan }
County of Livingston }
Township of Hamburg }

I, BRITTANY K. CAMPBELL, Hamburg Township Utilities Coordinator and recording
secretary to the Municipal Utilities Committee, do hereby certify that the foregoing is a true and
correct excerpt of the Minutes of the aforementioned Regular/~~Special~~ Meeting of the Hamburg
Township Municipal Utilities Committee.


BRITTANY K. CAMPBELL
HAMBURG TOWNSHIP UTILITIES COORDINATOR

Date: July 10th, 2024



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

To: Municipal Utilities Committee
From: Tony Randazzo
Date: 07-03-2024
Re: DPW Monthly Report

-
1. The wastewater treatment plant was in compliance for the month of June.
 2. Biotech came out and emptied only half of sludge tank # 4, which will give us two to three weeks of room. They plan on returning sooner than that and finishing the haul once the wheat has been harvested from our field.
 3. One of our part time on-call workers quit so we are once again looking to fill the position.
 4. We will begin the PFAS grant work this month now that the contract has been signed with EGLE.



Hamburg Township Monthly Field Report

June 2024

Ryan Ward

Grinder Calls: 37 Total / 15 OT

Plant Calls: 3 OT

Station Calls: 3 Hamburg/ 0 Portage

Pump Rebuilds: 29 Hamburg / 5 Portage / 7 Highland

Miss Digs: 193 Hamburg / 29 Portage

Startups: 0

Deactivations/Reactivations: 0

Replacements: 1

Grinder Stations in Stock: 81 simplex / 2 duplex

Grinder Locations: 1

Grinder Pump Cores in Stock: 32 + 2 for Duplex

Field Jobs for the Month: This month we have completed our normal monthly checks along with the water meter readings and grease trap inspections. We received our EONE delivery of 55 simplex stations and 1 duplex station. C&E Construction started the Tree Top court main extension and grinder pump installation. There was a lateral break at

8655 Country Club caused by a power outage, once the power came back on and all the grinder pumps started pumping and the main line had too much pressure causing this home's check valve to break. Biotech has arrived with equipment to start hauling our sludge. The plant has been in compliance for June 2024.

