



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

EXCERPT FROM HAMBURG TOWNSHIP MUNICIPAL UTILITIES COMMITTEE MEETING MINUTES

To the attention of: Patrick J. Hohl, Supervisor
Hamburg Township Board of Trustees

Re: **DPW Monthly Report – November 2022 Statistics**

Please be apprised of this excerpt from the ☒ Unapproved ☐ Approved Minutes of the Meeting of the Hamburg Township Sewer Committee:

Date of Meeting: December 14th, 2022

Sewer Committee Members Present: Hohl, Hahn, Michniewicz

Sewer Committee Members Absent: None


Text of Motion: MOTION BY HOHL, SUPPORTED BY MICHNIEWICZ TO NOTE THE DPW MONTHLY REPORT AS RECEIVED AND TO BE FILED AND TO ALSO FORWARD A COPY TO THE TOWNSHIP BOARD AS AN AGENDA ITEM FOR THEIR REVIEW.

Ayes: Hohl, Hahn, Michniewicz Absent: None Nays: None

MOTION CARRIED.

State of Michigan }
County of Livingston }
Township of Hamburg }

I, BRITTANY K. CAMPBELL, Hamburg Township Utilities Coordinator and recording secretary to the Municipal Utilities Committee, do hereby certify that the foregoing is a true and correct excerpt of the Minutes of the aforementioned Regular/~~Special~~ Meeting of the Hamburg Township Municipal Utilities Committee.


BRITTANY K. CAMPBELL
HAMBURG TOWNSHIP UTILITIES COORDINATOR

Date: December 15th, 2022



10405 Merrill Road ♦ P.O. Box 157
Hamburg, MI 48139
Phone: 810.231.1000 ♦ Fax: 810.231.4295
www.hamburg.mi.us

To: Municipal Utilities Committee
From: Tony Randazzo
Date: 12-07-2022
Re: DPW Monthly Report

-
1. The wastewater treatment plant was in compliance for the month of November.
 2. C&E Construction will resume construction of the sewer extension next week as their manholes and gate valves have arrived.
 3. At EGLE's request, we sampled four of our monitoring wells and also the well at Dairy Queen for PFAS. The Dairy Queen well results were all non-detect for PFAS. However, our monitoring wells all had positive hits for PFAS, although in very low amounts for the two wells closest to M-36. The next step is testing two residential wells near monitoring well #9.



Hamburg Township Monthly Field Report

November 2022

Ryan Ward

Grinder Calls: 47 Total / 29 OT

Plant Calls: 1 OT

Station Calls: 0

Pump Rebuilds: 27 Hamburg / 0 Portage / 3 Highland

Miss Digs: 146 Hamburg / 23 Portage

Startups: 4

Deactivations/Reactivations: 2

Replacements: 0

Field Jobs for the Month: This month we have completed our normal monthly checks along with the monitoring well sampling. Jon Sharp and I have also sampled monitoring wells 3a, 6, 13, 16 for PFAS. C&E has finished the boring part of the Pettysville main extension job, they will be resuming the project on 12/12 installing the manholes. We have received our new pump for Kress station, this will be installed by Kennedy Industries on 12/15.

