



10405 Merrill Road ♦ P.O. Box 157  
Hamburg, MI 48139  
Phone: 810.231.1000 ♦ Fax: 810.231.4295  
www.hamburg.mi.us

## EXCERPT FROM HAMBURG TOWNSHIP MUNICIPAL UTILITIES COMMITTEE MEETING MINUTES

To the attention of: Jason B. Negri, Supervisor  
Hamburg Township Board of Trustees

Re: **DPW Monthly Report – December 2025/January 2026 Statistics**

Please be apprised of this excerpt from the  Unapproved  Approved Minutes of the Meeting of the Hamburg Township Sewer Committee:

Date of Meeting: February 10<sup>th</sup>, 2026

Sewer Committee Members Present: Negri, Daniels

Sewer Committee Members Absent: Menzies

Text of Motion: MOTION BY NEGRI, SECONDED BY DANIELS TO NOTE THE DPW MONTHLY REPORT AS RECEIVED AND TO BE FILED AND TO ALSO FORWARD A COPY TO THE TOWNSHIP BOARD AS AN AGENDA ITEM FOR THEIR REVIEW.

Ayes: Negri, Daniels Absent: Menzies Nays: None

MOTION CARRIED.

State of Michigan }  
County of Livingston }  
Township of Hamburg }

I, BRITTANY K. CAMPBELL, Hamburg Township Utilities Coordinator and recording secretary to the Municipal Utilities Committee, do hereby certify that the foregoing is a true and correct excerpt of the Minutes of the aforementioned Regular/~~Special~~ Meeting of the Hamburg Township Municipal Utilities Committee.

 Date: February 10<sup>th</sup>, 2026  
BRITTANY K. CAMPBELL  
HAMBURG TOWNSHIP UTILITIES COORDINATOR



10405 Merrill Road ♦ P.O. Box 157  
Hamburg, MI 48139  
Phone: 810.231.1000 ♦ Fax: 810.231.4295  
[www.hamburg.mi.us](http://www.hamburg.mi.us)

To: Municipal Utilities Committee  
From: Tony Randazzo  
Date: 02-05-2026  
Re: DPW Monthly Report

- 
1. The daily testing at the wastewater treatment plant was in compliance for the months of December and January.
  2. I submitted our quarterly report for the PFAS grant. In the last two months, we have tested our remaining monitoring wells and started effluent sampling. EGLE has informed me that they want to sample additional homes for PFAS. We have a meeting scheduled for 2/18 to discuss next steps.
  3. Our inventory of simplex grinder pumps is down to sixteen. With several new homes expected to connect to sewer this spring, we'll need to place an order for a truckload of grinder pumps before the end of this fiscal year.



## **Hamburg Township Monthly Field Report**

**January 2026**

**Ryan Ward**

**Grinder Calls: 77 Total / 46 OT**

**Plant Calls: 0 OT**

**Station Calls: 0 Hamburg/ 1 Portage**

**Pump Rebuilds: 35 Hamburg / 4 Portage / 4 Highland / 2 Scrapped**

**Miss Digs: 47 Hamburg / 23 Portage**

**Startups: 0**

**Deactivations/Reactivations: 0**

**Replacements: 0**

**Grinder Stations in Stock: 16 simplex / 2 duplex**

**Grinder Locations: 2**

**Grinder Pump Cores in Stock: 20 + 2 for Duplex**

**WWTP Average Influent Flow: 310841 Gallons**

**Field Jobs for the Month: This month we have completed our normal monthly checks. The new pump has been installed at Kress station by Kerr Pump. ART has completed the touch up coating for Hamburg station, touch ups were made around the 5 pipes that exit and enter**

**the wet well. The sewer system experienced a lot of frozen grinder calls this month, we are hoping for warmer weather soon.**





## **Hamburg Township Monthly Field Report**

**December 2025**

**Ryan Ward**

**Grinder Calls: 39 Total / 20 OT**

**Plant Calls: 0 OT**

**Station Calls: 0 Hamburg/ 1 Portage**

**Pump Rebuilds: 19 Hamburg / 2 Portage / 2 Highland / 5 Scrapped**

**Miss Digs: 118 Hamburg / 36 Portage**

**Startups: 2**

**Deactivations/Reactivations: 0**

**Replacements: 0**

**Grinder Stations in Stock: 16 simplex / 2 duplex**

**Grinder Locations: 0**

**Grinder Pump Cores in Stock: 20 + 2 for Duplex**

**WWTP Average Influent Flow: 297950 Gallons**

**Field Jobs for the Month: This month we have completed our normal monthly checks along with the water meter readings and grease trap inspections. Biotech has completed a sludge haul, and land applied the solids to a field in Howell off Oak Grove Rd. The annual plant**

measuring meter calibrations have been done for Hamburg and Portage. Monitoring wells 10,17,18,19,20, and Effluent have been sampled for PFAS, we look to continue sampling each month. The Hamburg plant received a DelPac chemical delivery on the 5<sup>th</sup> of 2500 gallons.

