
VILLAGE BOARD MEETING**From:**

Chad Pelishek, Village Manager

VILLAGE OF HARRISON**Meeting Date:**

12/16/2025

Title: Village Hall: Water Treatment System

Recommended Action:

Motion to accept water treatment system at Village Hall for \$29,175.

Background and Additional Information:

The well water at Village Hall is very hard and sulfur smelling. Over the years the water has corroded the pipes and fixtures requiring replacement sooner than should be required. Also, with adding showers in DPW, additional pressure washer and new restrooms, having filtered water that smells better and is not super hard will allow our investments to last longer.

Furman Plumbing, Heating and Cooling provides well and pump service at Village Hall. Furman tested the water and make recommendations based on the water tests.

A second quote was required from Culligan. Culligan did not come on site and nor did they take any water samples.

Funds for this improvement would come from Hwy Dept- Equipment funds.

Budget Impact:

\$29,175 – 100-09-53311-600-600- Hwy Dept- Equip. Maintenance

Attachments:

- Quote from Fuhrmann Heating and Cooling