

# HARTFORD PUBLIC WORKS DEPARTMENT

City of Hartford 621-3022  
Justin Ryan Supt.



11/21/2022

## MAINTENANCE DEPARTMENT

Serviced all the equipment that required servicing  
Repaired all the equipment that required repairing  
Mow all city lots as needed.  
Clean and sweep parking lots.  
Had new motor put in 4x4 pickup.  
Mowed Waste Water Treatment Plant  
Had new motor put in 4x4 pickup.  
Helping at WWTP.

## WATER DEPARTMENT

Water turn off	2
Water turn on	1
Water meter repairs	2
Water leaks repaired	2
Water meters read by request	6
Water services replaced to water main	1
Collected monthly water samples and delivered to Paw Paw Lab	
Sent monthly reports to the Michigan Department of Health	
Ran auxiliary well generator once a week	
Water meters read for the month	
Working with contractors on lead/copper line inspections	

## MAJOR AND LOCAL STREETS

Picking up leafs  
Doing a lot of cold patch work.

## SEWER SYSTEM

Sewer mains rodded	5
Sewer services dug up and repaired	2
Mowed all lift stations	

## LIFT STATIONS

Lift stations are running very well at this time  
Generators are run once a week for testing  
Bar screens are cleaned twice a week

## Iron Removal Plant

Run back up generator once a week.  
Back wash twice a week.

# HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.  
621-3022  
Dan Staunton Supt.



11/21/2022

## WATER QUALITY AVERAGE FOR THE MONTH

### Raw Water

Iron	<u>1.53</u>	ppm
Manganese	<u>0.149</u>	ppm
pH	<u>7.2</u>	

### Finished Water

Iron	<u>0.001</u>	ppm
Manganese	<u>0</u>	ppm
Chlorine	<u>1</u>	ppm
Phosphates	<u>1.4</u>	ppm
Flouride	<u>0.8</u>	ppm
pH	<u>7.2</u>	

### Chemicals used

Chlorine	<u>111</u>	Total Lbs
Phosphates	<u>219</u>	
Flouride	<u>200</u>	

### Average Daily Use

3.5	
<u>6</u>	
<u>5.6</u>	

## WATER PUMPED FOR THE MONTH

Backwash water 4.970 Million Gallons

174,000 Gallons

## WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.	<u>ND</u>
525 E. Main St.	<u>ND</u>
200 Beachwood St.	<u>ND</u>
Well#6	<u>ND</u>