



October 2025 Monthly Operations Summary

City of Hartford – Drinking Water System

SUMMARY:

Routine O&M, monitoring, and compliance activities continued.

Water Quality Improvements

- Working with the engineers to switch oxidations methods in order to address taste/odor and better manage iron and manganese

Maintenance and Operations

- **Back Up Power** – Back generator is now being exercised twice a month, and one of those times the plant and wells are switched to back up power to ensure reliability
- **Training** – We have been training some of the DPW staff on routine operations and even hosted staff at our operator training classes held in Cassopolis

Looking Ahead – Nov 2025

- **Respond to EGLE Sanitary Survey** – Response submitted
- **Continue distribution system monitoring** – Collect data to evaluate and maintain recent water quality improvements.
- **Schedule cathodic protection inspection** – We've been in touch with CorrPro and anticipate to firm date soon.

FLOWS:

- October 2025
 - Total – 7.482 MG
 - Max Daily – 0.294 MGD
 - Avg Daily – 0.241 MGD
- September 2025
 - Total – 6.276 MG
 - Max Daily – 0.313 MGD
 - Avg Daily – 0.209 MGD
- October 2024
 - Total – 5.702 MG
 - Max Daily - 0.219 MGD
 - Avg Daily - 0.184 MGD