

HARTFORD PUBLIC WORKS DEPARTMENT

Dan Staunton Supt.
Public Works



9/25/2023

MAINTENANCE DEPARTMENT

Serviced all the equipment that required servicing
Repaired all the equipment that required repairing
Picked up brush.
Cut brush.
Do all the mowing that needed to be done.
Remove tree that fell on S. Center St.

WATER DEPARTMENT

Water turn off	<u>1</u>
Water turn on	<u>1</u>
Water meter repairs	<u>2</u>
Water leaks repaired	<u>1</u>
Water meters read by request	<u>4</u>
Water services replaced to water main	<u>6</u>
Collected monthly water samples and delivered to Paw Paw Lab	
Sent monthly reports to the Michigan Department of Health	
Ran auxiliary well generator once a week	
Working with contractors	

MAJOR AND LOCAL STREETS

Cold patching as needed.

SEWER SYSTEM

Sewer mains rodded	<u>2</u>
Sewer services dug up and repaired	<u>0</u>

LIFT STATIONS

Lift stations are running very well at this time
Generators are run once a week for testing
Bar screens are cleaned twice a week

Iron Removal Plant

Run back up generator once a week.

HARTFORD PUBLIC WORKS DEPARTMENT

Dan Staunton Supt.
Public Works



9/25/2023

WATER QUALITY AVERAGE FOR THE MONTH

Raw Water

Iron 1.52 ppm
Manganese 0.149 ppm
pH 7.4

Finished Water

Iron 0 ppm
Manganese 0 ppm
Chlorine 1.1 ppm
Phosphates 1.4 ppm
Flouride 0.7 ppm
pH 7.4

Chemicals used

Chemicals used	Total Lbs
Chlorine	<u>118.1</u>
Phosphates	<u>206</u>
Flouride	<u>189.4</u>

Average Daily Use

<u>3.8</u>
<u>6.6</u>
<u>6.1</u>

WATER PUMPED FOR THE MONTH

Backwash water

5.780 Million Gallons
152,000 Gallons

WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.
525 E. Main St.
200 Beachwood St.
Well#6

ND
ND
ND
ND