

HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.
621-3022
Justin Ryan Supt.



3/27/2023

MAINTENANCE DEPARTMENT

Serviced all the equipment that required servicing
Repaired all the equipment that required repairing
Haul snow as needed.
Plow snow as needed,
Take down school banners
Clean park.
Empty trash cans.

WATER DEPARTMENT

Water turn off	1
Water turn on	1
Water meter repairs	1
Water leaks repaired	1
Water meters read by request	4
Water services replaced to water main	0
Collected monthly water samples and delivered to Paw Paw Lab	
Sent monthly reports to the Michigan Department of Health	
Ran auxiliary well generator once a week	

MAJOR AND LOCAL STREETS

Cold patching as needed.
Plow snow as needed.

SEWER SYSTEM

Sewer mains rodded	3
Sewer services dug up and repaired	0

LIFT STATIONS

Lift stations are running very well at this time
Generators are run once a week for testing
Bar screens are cleaned twice a week

Iron Removal Plant

Run back up generator once a week.

HARTFORD PUBLIC WORKS DEPARTMENT

Iron Removal Plant.
Dan Staunton.



3/27/2023

WATER QUALITY AVERAGE FOR THE MONTH

Raw Water	Finished Water
Iron	0.001 ppm
Manganese	0.001 ppm
pH	7.2
Chemicals used	Total Lbs
Chlorine	116
Phosphates	199
Flouride	195
	Average Daily Use
	4.1
	7.1
	6.1

WATER PUMPED FOR THE MONTH
Backwash water

5.100 Million Gallons
153,000 Gallons

WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.	ND
525 E. Main St.	ND
200 Beachwood St.	ND