

# HARTFORD PUBLIC WORKS DEPARTMENT

200 Beechwood St. Dan  
Staunton Supt.



6/12/2023

## MAINTENANCE DEPARTMENT

Serviced all the equipment that required servicing  
Repaired all the equipment that required repairing  
Clean park as needed.  
Water flowers three times a wekk.  
Empty trash cans as needed.  
Working with contractors on Clark Linden St. projects.

## WATER DEPARTMENT

Water turn off	<u>1</u>
Water turn on	<u>1</u>
Water meter repairs	<u>2</u>
Water leaks repaired	<u>1</u>
Water meters read by request	<u>8</u>
Water services replaced to water main	<u>1</u>
Collected monthly water samples and delivered to Paw Paw Lab	
Sent monthly reports to the Michigan Department of Health	
Ran auxiliary well generator once a week	

## MAJOR AND LOCAL STREETS

Cold patching as needed.  
Cleaning and sweeping curbs

## SEWER SYSTEM

Sewer mains rodded	<u>4</u>
Sewer services dug up and repaired	<u>0</u>

## LIFT STATIONS

Lift stations are running very well at this time  
Generators are run once a week for testing  
Bar screens are cleaned twice a week

## Iron Removal Plant

Run back up generator once a week.

# HARTFORD PUBLIC WORKS DEPARTMENT

200 Beechwood St. Dan  
Staunton Supt.



6/12/2023

## WATER QUALITY AVERAGE FOR THE MONTH

### Raw Water

Iron 1.54 ppm  
Manganese 0.149 ppm  
pH 7.2

### Finished Water

Iron 0 ppm  
Manganese 0 ppm  
Chlorine 1.1 ppm  
Phosphates 1.3 ppm  
Flouride 0.8 ppm  
pH 7.2

### Chemicals used

	<u>Total Lbs</u>
Chlorine	<u>118.1</u>
Phosphates	<u>222</u>
Flouride	<u>173.5</u>

### Average Daily Use

	<u>Average Daily Use</u>
	<u>3.8</u>
	<u>7.1</u>
	<u>5.5</u>

## WATER PUMPED FOR THE MONTH

Backwash water

6.136 Million Gallons  
210,000 Gallons

## WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.  
525 E. Main St.  
200 Beachwood St.

ND  
ND  
ND