

HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.
621-3022
Dan Staunton Supt.



3/22/2021

MAINTENANCE DEPARTMENT

Serviced all the equipment that required servicing
Repaired all the equipment that required repairing
Haul snow from parking lots.
Plow sidewalks on Main St and Center St.
Snow removal as needed
Clean sidewalks and curbs in busines district.

WATER DEPARTMENT

Water turn off	<u>2</u>
Water turn on	<u>0</u>
Water meter repairs	<u>3</u>
Water leaks repaired	<u>2</u>
Water meters read by request	<u>3</u>
Water services replaced to water main	<u>1</u>

Collected monthly water samples and delivered to Paw Paw Lab
Sent monthly reports to the Michigan Department of Health
Ran auxiliary well generator once a week
Water meters read for the month.

MAJOR AND LOCAL STREETS

Snow removal as needed.
Cold patching.

SEWER SYSTEM

Sewer mains rodded	<u>4</u>
Sewer services dug up and repaired	<u>0</u>

Sewer main replaced on Linden St.

LIFT STATIONS

Lift stations are running very well at this time
Generators are run once a week for testing
Bar screens are cleaned twice a week

Iron Removal Plant

Backwash twice a week.

HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.
621-3022
Dan Staunton Supt.



3/22/2021

WATER QUALITY AVERAGE FOR THE MONTH

Raw Water

Iron 1.59 ppm
Manganese 0.158 ppm
pH 7.9

Finished Water

Iron 0.001 ppm
Manganese 0.001 ppm
Chlorine 1.2 ppm
Phosphates 1.7 ppm
Flouride 0.7 ppm
pH 7.9

Chemicals used

	<u>Total Lbs</u>
Chlorine	<u>101.5</u>
Phosphates	<u>103.5</u>
Flouride	<u>188.6</u>

Average Daily Use

<u>3.6</u>
<u>3.7</u>
<u>6.7</u>

WATER PUMPED FOR THE MONTH

Backwash water

4.563 Million Gallons
145,000 Gallons

WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.
525 E. Main St.
200 Beachwood St.

ND
ND
ND