

HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.
621-3022
Dan Staunton Supt.



5/24/2021

MAINTENANCE DEPARTMENT

Serviced all the equipment that required servicing
Repaired all the equipment that required repairing
Pick up Ely Park and mow grass.
Mowed city lots.
Empty trash cans every week.
Put up school banners.
Mow waste water treatment plant.
Pickup brush and leaves.

WATER DEPARTMENT

Water turn off	<u>2</u>
Water turn on	<u>1</u>
Water meter repairs	<u>3</u>
Water leaks repaired	<u>1</u>
Water meters read by request	<u>5</u>
Water services replaced to water main	<u>1</u>

Collected monthly water samples and delivered to Paw Paw Lab
Sent monthly reports to the Michigan Department of Health
Ran auxiliary well generator once a week
Read water meters for the month.

MAJOR AND LOCAL STREETS

Clean streets up town.
Cold patching

SEWER SYSTEM

Sewer mains rodded	<u>5</u>
Sewer services dug up and repaired	<u>1</u>

LIFT STATIONS

Lift stations are running very well at this time
Generators are run once a week for testing
Bar screens are cleaned twice a week

Iron Removal Plant

Mow grass as needed.

HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.
621-3022
Dan Staunton Supt.



5/24/2021

WATER QUALITY AVERAGE FOR THE MONTH

Raw Water

Iron 1.54 ppm
Manganese 0.155 ppm
pH 7.8

Finished Water

Iron 0.001 ppm
Manganese 0.001 ppm
Chlorine 1.1 ppm
Phosphates 1.8 ppm
Flouride 0.9 ppm
pH 7.9

Chemicals used

	Total Lbs
Chlorine	<u>99.7</u>
Phosphates	<u>113</u>
Flouride	<u>203</u>

Average Daily Use

<u>3.3</u>
<u>3.8</u>
<u>6.8</u>

WATER PUMPED FOR THE MONTH

4.963 Million Gallons

Backwash water 218,000 Gallons

WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.	<u>ND</u>
525 E. Main St.	<u>ND</u>
200 Beachwood St.	<u>ND</u>