

# HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.  
621-3022  
Dan Staunton Supt.



March, 2024

## MAINTENANCE DEPARTMENT

Serviced all the equipment that required servicing  
Repaired all the equipment that required repairing  
Cleaned off storm drains.  
Picked up brush.  
Cleaned park.  
Replaced starters on both pickups.

## WATER DEPARTMENT

Water turn off	1
Water turn on	2
Water meter repairs	5
Water leaks repaired	1
Water meters read by request	5
Water services replaced to water main	0

Collected monthly water samples and delivered to Paw Paw Lab  
Sent monthly reports to the Michigan Department of Health  
Ran auxiliary well generator once a week

## MAJOR AND LOCAL STREETS

Cold patching as needed.  
Snow and ice removal.

## SEWER SYSTEM

Sewer mains rodded	3
Sewer services dug up and repaired	0

## LIFT STATIONS

Lift stations are running very well at this time  
Generators are run once a week for testing  
Bar screens are cleaned twice a week

## Iron Removal Plant

Run back up generator once a week.  
Doing some painting in IRP

# HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.  
621-3022  
Dan Staunton Supt.



March, 2024

## WATER QUALITY AVERAGE FOR THE MONTH

### Raw Water

Iron 1.4 ppm  
Manganese 0.139 ppm  
pH 7.1

### Finished Water

Iron 0 ppm  
Manganese 0 ppm  
Chlorine 1 ppm  
Phosphates 1.1 ppm  
Flouride 0.8 ppm  
pH \_\_\_\_\_

### Chemicals used

	Total Lbs
Chlorine	<u>99.3</u>
Phosphates	<u>179</u>
Flouride	<u>156</u>

### Average Daily Use

<u>3.4</u>
<u>6.1</u>
<u>5.3</u>

## WATER PUMPED FOR THE MONTH

Backwash water

4.688 Million Gallons  
133,000 Gallons

## WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.  
525 E. Main St.  
200 Beachwood St.

ND  
ND  
ND