

# HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.  
621-3022  
Ricky Ricks Supt.



June, 2025

## MAINTENANCE DEPARTMENT

Serviced all equipment  
Put up banners  
Put out flower pots  
Water flowers 3 times a week  
Mowed all city property  
Helped with Strawberry Festival  
Empty trash cans

## WATER DEPARTMENT

Water turn off	<u>2</u>
Water turn on	<u>1</u>
Water meter repairs	<u>10</u>
Water leaks repaired	<u>1</u>
Water meters read by request	<u>11</u>
Water services replaced to water main	<u>0</u>
Collected monthly water samples and delivered to Paw Paw Lab	
Sent monthly reports to the Michigan Department of Health	
Ran auxiliary well generator once a week	

## MAJOR AND LOCAL STREETS

Picked up brush  
Cold patching

## SEWER SYSTEM

Sewer mains rodded	<u>2</u>
Sewer services dug up and repaired	<u>0</u>

## LIFT STATIONS

Lift stations are running very well at this time  
Generators are run once a week for testing  
Bar screens are cleaned twice a week

## Iron Removal Plant

Run back up generator once a week.

# IRON REMOVAL PLANT

62822 Red Arrow Hwy  
621- 6505 IRP  
Quentin Clark



6/23/2025

## WATER QUALITY AVERAGE FOR THE MONTH

### Raw Water

Iron	<u>1.32</u>	ppm
Manganese	<u>0.141</u>	ppm
pH	<u>7.4</u>	

### Finished Water

Iron	<u>0.003</u>	ppm
Manganese	<u>0.002</u>	ppm
Chlorine	<u>1.1</u>	ppm
Phosphates	<u>1.2</u>	ppm
Flouride	<u>0.8</u>	ppm
pH	<u>7.4</u>	

### Chemicals used

Chlorine	<u>91.8</u>
Phosphates	<u>175</u>
Flouride	<u>121</u>

### Total Lbs

### Average Daily Use

<u>3</u>
<u>5.8</u>
<u>4</u>

## WATER PUMPED FOR THE MONTH

Backwash water

<u>5.207</u>	Million Gallons
<u>184,000</u>	Gallons

## WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.  
525 E. Main St.  
200 Beachwood St.

<u>ND</u>
<u>ND</u>
<u>ND</u>