

# HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.  
621-3022  
Dan Staunton Supt.



7/25/2022

## MAINTENANCE DEPARTMENT

Serviced all the equipment that required servicing  
Repaired all the equipment that required repairing  
Mow all city lots as needed.  
Clean and sweep parking lots.  
Picking up brush.  
Mowed Waste Water Treatment Plant  
Had four bad trees cut down.

## WATER DEPARTMENT

Water turn off	<u>2</u>
Water turn on	<u>1</u>
Water meter repairs	<u>1</u>
Water leaks repaired	<u>1</u>
Water meters read by request	<u>4</u>
Water services replaced to water main	<u>0</u>

Collected monthly water samples and delivered to Paw Paw Lab  
Sent monthly reports to the Michigan Department of Health  
Ran auxiliary well generator once a week  
Water meters read for the month

## MAJOR AND LOCAL STREETS

Repair sink hole North Haver St.  
Doing a lot of cold patch work.

## SEWER SYSTEM

Sewer mains rodded	<u>1</u>
Sewer services dug up and repaired	<u>0</u>

## LIFT STATIONS

Lift stations are running very well at this time  
Generators are run once a week for testing  
Bar screens are cleaned twice a week

## Iron Removal Plant

Run back up generator once a week.  
Back wash twice a week.

# HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.  
621-3022  
Dan Staunton Supt.



7/25/2022

## WATER QUALITY AVERAGE FOR THE MONTH

### Raw Water

Iron 1.57 ppm  
Manganese 0.149 ppm  
pH 7.2

### Finished Water

Iron 0.001 ppm  
Manganese 0.001 ppm  
Chlorine 1 ppm  
Phosphates 1.3 ppm  
Flouride 0.8 ppm  
pH 7.3

### Chemicals used

	<u>Total Lbs</u>
Chlorine	<u>123.8</u>
Phosphates	<u>209</u>
Flouride	<u>185</u>

### Average Daily Use

<u>4.1</u>
<u>6.9</u>
<u>6.1</u>

## WATER PUMPED FOR THE MONTH

Backwash water

5.490 Million Gallons

160,000 Gallons

## WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.  
525 E. Main St.  
200 Beachwood St.  
Well#6

ND  
ND  
ND  
ND