

HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.
621-3022
Ricky Ricks Supt.



February, 2025

MAINTENANCE DEPARTMENT

Serviced all equipment that needed servicing.
Had radiator replaced in International dump truck.
Replaced batterys in trailer generator.
Plowed sidewalks.
Put up school banners.

WATER DEPARTMENT

Water turn off	<u>1</u>
Water turn on	<u>0</u>
Water meter repairs	<u>10</u>
Water leaks repaired	<u>1</u>
Water meters read by request	<u>12</u>
Water services replaced to water main	<u>1</u>
Collected monthly water samples and delivered to Paw Paw Lab	
Sent monthly reports to the Michigan Department of Health	
Ran auxilliary well generator once a week	

MAJOR AND LOCAL STREETS

Snow removal as needed.
Cold patching.
Cleaned off storm sewer inlets.
Salted intersections.

SEWER SYSTEM

Sewer mains rodded	<u>5</u>
Sewer services dug up and repaired	<u>0</u>

LIFT STATIONS

Lift stations are running very well at this time
Generators are run once a week for testing
Bar screens are cleaned twice a week

Iron Removal Plant

Run back up generator once a week.
Had pump rebuilt in liftstation 372.

IRON REMOVAL PLANT

62822 Red Arrow Hwy
621-6505
Dan Staunton



February, 2025

WATER QUALITY AVERAGE FOR THE MONTH

Raw Water

Iron 1.51 ppm
Manganese 0.149 ppm
pH 7.2

Finished Water

Iron 0 ppm
Manganese 0 ppm
Chlorine 1.1 ppm
Phosphates 1.2 ppm
Flouride 0.8 ppm
pH 7.2

Chemicals used

Chlorine 109.2
Phosphates 190
Flouride 184

Total Lbs

Average Daily Use

3.5
6.1
5.9

WATER PUMPED FOR THE MONTH

Backwash water

6.081 Million Gallons
184,000 Gallons

WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.
525 E. Main St.
200 Beachwood St.

ND
ND
ND