

# HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.  
621-3022  
Dan Staunton Supt.



May, 2024

## MAINTENANCE DEPARTMENT

Serviced all the equipment that required servicing  
Repaired all the equipment that required repairing  
Picked up leaves.  
Picked up brush.  
Cleaned park  
Put out trash cans  
Opened rest rooms in park.

## WATER DEPARTMENT

Water turn off  
Water turn on  
Water meter repairs  
Water leaks repaired  
Water meters read by request  
Water services replaced to water main  
Collected monthly water samples and delivered to Paw Paw Lab  
Sent monthly reports to the Michigan Department of Health  
Ran auxiliary well generator once a week  
Flushed fire hydrants.

2
1
9
1
10
0

## MAJOR AND LOCAL STREETS

Cold patching as needed.  
Cleaned storm drains.

## SEWER SYSTEM

Sewer mains rodded  
Sewer services dug up and repaired

4
0

## LIFT STATIONS

Lift stations are running very well at this time  
Generators are run once a week for testing  
Bar screens are cleaned twice a week

## Iron Removal Plant

Run back up generator once a week.

# HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.  
621-3022  
Dan Staunton Supt.



May, 2024

## WATER QUALITY AVERAGE FOR THE MONTH

### Raw Water

Iron	<u>1.41</u> ppm
Manganese	<u>0.139</u> ppm
pH	<u>7.1</u>

### Finished Water

Iron	<u>0.001</u> ppm
Manganese	<u>0.002</u> ppm
Chlorine	<u>1</u> ppm
Phosphates	<u>1.1</u> ppm
Flouride	<u>0.8</u> ppm
pH	<u>7.2</u>

### Chemicals used

	<b>Total Lbs</b>
Chlorine	<u>107</u>
Phosphates	<u>198</u>
Flouride	<u>171</u>

### Average Daily Use

<u>3.5</u>
<u>6.6</u>
<u>5.7</u>

## WATER PUMPED FOR THE MONTH

Backwash water	<u>5.210</u> Million Gallons
	<u>225,000</u> Gallons

## WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.	<u>ND</u>
525 E. Main St.	<u>ND</u>
200 Beachwood St.	<u>ND</u>