

# HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.  
621-3022  
Dan Staunton Supt.



2/28/2022

## MAINTENANCE DEPARTMENT

Serviced all the equipment that required servicing  
Repaired all the equipment that required repairing  
Haul snow from parking lots  
Take down Christmas decorations.  
Snow removal as needed

## WATER DEPARTMENT

Water turn off	2
Water turn on	1
Water meter repairs	3
Water leaks repaired	1
Water meters read by request	5
Water services replaced to water main	1

Collected monthly water samples and delivered to Paw Paw Lab  
Sent monthly reports to the Michigan Department of Health  
Ran auxiliary well generator once a week  
Water meters read for the month of December

## MAJOR AND LOCAL STREETS

Snow removal as needed.  
Did some cold patching

## SEWER SYSTEM

Sewer mains rodded	3
Sewer services dug up and repaired	0

## LIFT STATIONS

Lift stations are running very well at this time  
Generators are run once a week for testing  
Bar screens are cleaned twice a week  
Replaced pump one in lift station 372.  
**Iron Removal Plant**  
Run back up generator once a week.  
Back wash twice a week.  
Replaced VFD drive in well # 6

# HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.  
621-3022  
Dan Staunton Supt.



2/28/2022

## WATER QUALITY AVERAGE FOR THE MONTH

### Raw Water

Iron 1.56 ppm  
Manganese 0.161 ppm  
pH 7.7

### Finished Water

Iron 0 ppm  
Manganese 0.001 ppm  
Chlorine 1 ppm  
Phosphates 1.8 ppm  
Flouride 0.8 ppm  
pH 7.7

### Chemicals used

Chlorine 96.5  
Phosphates 99.5  
Flouride 189.6

### Total Lbs

### Average Daily Use

3.1  
3.2  
6.1

## WATER PUMPED FOR THE MONTH

Backwash water

5.197 Million Gallons  
177,000 Gallons

## WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.  
525 E. Main St.  
200 Beachwood St.  
Well#4

ND  
ND  
ND  
ND