HARTFORD PUBLIC WORKS DEPARTMENT

200 Beechwood St.Public Works Dept. Ricky Ricks



October, 2024

MAINTENANCE DEPARTMENT

Serviced all the equipment that required servicing Repaired all the equipment that required repairing Picking up leafs
Picked up brush.
Clean restrooms daily
Mowing as needed.
Had kabota tractor repaired.

WATER DEPARTMENT

Water turn off	1
Water turn on	0
Water meter repairs	8
Water leaks repaired	0
Water meters read by request	8
Water services replaced to water main	0
Collected monthly water samples and delivered to Paw Paw Lab	
Sent monthly reports to the Michigan Department of Health	
Ran auxiliary well generator once a week	
Read water meters for the month	

MAJOR AND LOCAL STREETS

Cold patching as needed. Picking up brush

SEWER SYSTEM

Sewer mains rodded Sewer services dug up and repaired

LIFT STATIONS

Lift stations are running very well at this time Generators are run once a week for testing Bar screens are cleaned twice a week

Iron Removal Plant

Run back up generator once a week.

HARTFORD PUBLIC WORKS DEPARTMENT

200 Beechwood St.Public Works Dept. Ricky Ricks



October, 2024

WATER QUALITY AVERAGE FOR THE MONTH

Raw Water **Finished Water** Iron 1.32 ppm Iron ppm 0.137 ppm Manganese Manganese ppm рΗ 7.1 Chlorine 1.1 ppm Phosphates ppm Flouride ppm рН 7.1

Chemicals usedTotal LbsAverage Daily UseChlorine147.2Phosphates194Flouride185

WATER PUMPED FOR THE MONTH

Backwash water

6.170 Million Gallons 182,000 Gallons

WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St. 525 E. Main St. 200 Beachwood St.

ND ND ND