

HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.
621-3022
Ricky Ricks Supt.



April, 2025

MAINTENANCE DEPARTMENT

Serviced all equipment that needed service.
Put out trash cans.
Cleaned park up after winter.
Clean sidewalks off in main block.

WATER DEPARTMENT

Water turn off	1
Water turn on	2
Water meter repairs and replacment	30
Water leaks repaired	2
Water meters read by request	25
Water services replaced to water main	1
Collected monthly water samples and delivered to Paw Paw Lab	
Sent monthly reports to the Michigan Department of Health	
Ran auxiliary well generator once a week	
Water turn off and turn back non payment.	20

MAJOR AND LOCAL STREETS

Cold patching
Cleaned storm drains.
Salt streets as needed.

SEWER SYSTEM

Sewer mains rodded	8
Sewer services dug up and repaired	0
Ha Clean Earth root cut sewer main on Paris Hill Dr.	

LIFT STATIONS

Lift stations are running very well at this time
Generators are run once a week for testing
Bar screens are cleaned twice a week

Iron Removal Plant

Run back up generator once a week.

IRON REMOVAL PLANT

62822 Red Arrow Hwy
621-6505
Dan Staunton



April, 2025

WATER QUALITY AVERAGE FOR THE MONTH

Raw Water

Iron	<u>1.52</u> ppm
Manganese	<u>0.149</u> ppm
pH	<u>7.4</u>

Finished Water

Iron	<u>0</u> ppm
Manganese	<u>0</u> ppm
Chlorine	<u>1</u> ppm
Phosphates	<u>1.1</u> ppm
Flouride	<u>0.8</u> ppm
pH	<u> </u>

Chemicals used

	Total Lbs
Chlorine	<u>93.3</u>
Phosphates	<u>163</u>
Flouride	<u>145</u>

Average Daily Use

<u>3</u>
<u>5.2</u>
<u>4.6</u>

WATER PUMPED FOR THE MONTH

Backwash water

<u>5.706</u>	Million Gallons
<u>181,000</u>	Gallons

WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.
525 E. Main St.
200 Beachwood St.

<u>ND</u>
<u>ND</u>
<u>ND</u>