

WWTP Activities Report
12/11/24

- Removed old polymer tanks
- Greasing Equipment
- Flow equalization tank – learning – monitoring – had the company back in to troubleshoot following a power outage
- Took scrap metal to scrap yard
- Obtained quote for new generator batteries
- Influent and Effluent mercury sampling
- Collection system mercury sampling
- Routine preventative maintenance
- Sulfate sampling to Trace
- Monthly Discharge Monitoring report to EGLE
- Replaced Sodium Bisulfite Pump
- Biomass reduction on RBCs
- Meeting with Whightmans
- Received load of lime
- Had the generator serviced – leaking coolant line and regular service
- New propane tanks arriving today for heating