

HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.
621-3022
Dan Staunton Supt.



11/15/2021

MAINTENANCE DEPARTMENT

Serviced all the equipment that required servicing
Repaired all the equipment that required repairing
Mowed all the city's properties as needed.
Clean and open restrooms daily.
Empty trash cans weekly.
Put flower pots and trash cans away for winter.
Picked up brush.
Picking up leaves.

WATER DEPARTMENT

Water turn off	<u>2</u>
Water turn on	<u>1</u>
Water meter repairs	<u>2</u>
Water leaks repaired	<u>2</u>
Water meters read by request	<u>3</u>
Water services replaced to water main	<u>1</u>

Collected monthly water samples and delivered to Paw Paw Lab
Sent monthly reports to the Michigan Department of Health
Ran auxiliary well generator once a week
Water meters read for the month.

MAJOR AND LOCAL STREETS

Cold patching

SEWER SYSTEM

Sewer mains rodded	<u>3</u>
Sewer services dug up and repaired	<u>0</u>

LIFT STATIONS

Lift stations are running very well at this time
Generators are run once a week for testing
Bar screens are cleaned twice a week

Iron Removal Plant

Run generators once a week.

HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.
621-3022
Dan Staunton Supt.



11/15/2021

WATER QUALITY AVERAGE FOR THE MONTH

Raw Water

Iron 1.56 ppm
Manganese 0.149 ppm
pH 7.5

Finished Water

Iron 0 ppm
Manganese 0 ppm
Chlorine 1.2 ppm
Phosphates 1.8 ppm
Flouride 0.8 ppm
pH 7.6

Chemicals used

	<u>Total Lbs</u>
Chlorine	<u>162</u>
Phosphates	<u>268</u>
Flouride	<u>228</u>

Average Daily Use

	<u>Average Daily Use</u>
Chlorine	<u>5.2</u>
Phosphates	<u>8.6</u>
Flouride	<u>7.3</u>

WATER PUMPED FOR THE MONTH

6.430 Million Gallons

Backwash water 193 Gallons

WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.	<u>ND</u>
525 E. Main St.	<u>ND</u>
200 Beachwood St.	<u>ND</u>