HARTFORD WASTEWATER TREATMENT PLANT 66460 56th Ave * Hartford MI 49057 * 269-621-2289* cohwwtp@frontier.com

Tom Strand, HWWTP Operator

HWWTP Report for the Month of: October, 2021

- State report has been submitted for the month of October.
- Average flow 0.122 MGD (million gallons per day).
- Performed routine maintenance and daily duties.

Operation Report for October, 2021

Flow in Million Gallons Per Day	
A. Monthly Total	3.777
B. Average	0.122
Sodium Hypochlorite gallons Per Day	
A. Total	372
B. Average	12.0
Ferric in Gallons Per Day	
A. Total	729
B. Average	24
Polymer Powder in Pounds Per Day	
A. Total	31.00
B. Average	1.00
Sodium Bisulfite in Gallons Per Day	
A. Total	108.5
B. Average	3.5
Electric usage KWH	
A. Total	53
B. Average	1.7
Final BOD in Pounds	
A. Total	215
B. Average (177 LBS. Allowed)	10
C. % Removal (85%)	97
Final Suspended Solids in Pounds	
A. Total	273
B. Average (131 LBS. Allowed)	13
C. Average mg/l	13.0
D. % Removal (85%)	94
Total Phosphorus in mg/l	
A. 30 Day Average (1 mg/l Allowed)	0.5
B. % Removal	94
Fecal Coliform Bacteria in Count/100ml	
A. Average (200/100ml Allowed)	45
	B. Average Sodium Hypochlorite gallons Per Day A. Total B. Average Ferric in Gallons Per Day A. Total B. Average Polymer Powder in Pounds Per Day A. Total B. Average Sodium Bisulfite in Gallons Per Day A. Total B. Average Sodium Bisulfite in Gallons Per Day A. Total B. Average Electric usage KWH A. Total B. Average Final BOD in Pounds A. Total B. Average Final BOD in Pounds A. Total B. Average (177 LBS. Allowed) C. % Removal (85%) Final Suspended Solids in Pounds A. Total B. Average (131 LBS. Allowed) C. Average mg/l D. % Removal (85%) Total Phosphorus in mg/l A. 30 Day Average (1 mg/l Allowed) B. % Removal Fecal Coliform Bacteria in Count/100ml