

**CITY OF HARTFORD
COUNTY OF VAN BUREN
STATE OF MICHIGAN
RESOLUTION 2025– 040**



IRON REMOVAL PLANT – INFRASTRUCTURE WELL OVERHAUL

At a Regular meeting of the City of Hartford Commission, located at 19 West Main Street and called to order by Mayor Richard A. Hall on May 19, 2025

The following resolution was offered:

Moved by Commissioner _____ and supported by Commissioner _____.

WHEREAS, the Water Operator is recommending the City water source wells no. 4 and no. 5 be rebuilt/overhauled, and

WHEREAS, the well overhaul has been more than 20 years and is nearing the end of their service life and is also needed to stay in compliance with the City’s water operations permit, and

WHEREAS, to prevent any untimely breakdowns, it is recommended as a preventative overhaul, and

WHEREAS, it is not known the exact condition of the pumps until they are removed from the well, and

WHEREAS, the normal wearing parts are estimated to cost up to \$36,540, well no. 4 has been budgeted to be replaced in the current fiscal year, and well no. 5 in fiscal year 2025/2026, and

NOW THEREFORE, BE IT RESOLVED, that the City Council for the City of Hartford authorizes the rebuilding overhaul of wells no. 4 & 5 not to exceed \$40,000.00 for each well, and authorizes the City Manager to execute the contract.

YEAS: Commissioners’

NAYS: ABSENT: Commissioner

RESOLUTION DECLARED ADOPTED

DATE: May 19, 2025

RoxAnn Rodney-Isbrecht, City Clerk

I RoxAnn Rodney-Isbrecht, Clerk for the City of Hartford, do hereby certify that the foregoing is a true and complete copy of a Resolution duly adopted by the City Commission of the City of Hartford during a meeting held on May 19, 2025 and the public notice of said meeting was held in compliance with Act 267 of the Public Acts of Michigan of 1976, as amended.

DATE:

RoxAnn Rodney-Isbrecht, City Clerk
City of Hartford
19 West Main Street
Hartford MI 49057