IRON REMOVAL PLANT

62822 Red Arrow Hwy 621-6505 Dan Staunton



May, 2025

WATER QUALITY AVERAGE FOR THE MONTH

Raw Water **Finished Water** 1.46 ppm Iron 0.002 ppm Manganese 0.147 ppm Manganese 0.003 ppm 7.3 Chlorine рΗ 1 ppm Phosphates 1.2 ppm Flouride 7.4 ppm рΗ

 Chemicals used
 Total Lbs
 Average Daily Use

 Chlorine
 93
 3.1

 Phosphates
 170
 5.6

 Flouride
 131
 4.3

WATER PUMPED FOR THE MONTH

Backwash water

5.478 Million Gallons 182,000 Gallons

WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St. 525 E. Main St. 200 Beachwood St. ND ND