

Hartford WWTP Report
April 2024

1. The construction project continues to not make much progress.
2. EGLE performed an on-sight inspection. They want us to perform additional mercury testing.
3. Grit removal system wear bars were replaced
4. Daily sludge wasting
5. Weekly sludge transfers
6. Weekly preventative maintenance greasing
7. Daily equipment checks
8. Daily lab testing
9. Monthly testing by outside lab
10. Replaced snapped bolt on west primary clarifier
11. AM Hawk Sampling scheduled for 4/10/24
12. Biomass reduction on RBCs
13. Sodium bisulfite pump failed and was replace

Andrew Warner