

# HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.  
621-3022  
Dan Staunton Supt.



4/25/2022

## MAINTENANCE DEPARTMENT

Serviced all the equipment that required servicing  
Repaired all the equipment that required repairing  
Pickup City park.  
Clean and sweep parking lots.

## WATER DEPARTMENT

Water turn off	<u>1</u>
Water turn on	<u>2</u>
Water meter repairs	<u>3</u>
Water leaks repaired	<u>1</u>
Water meters read by request	<u>4</u>
Water services replaced to water main	<u>1</u>

Collected monthly water samples and delivered to Paw Paw Lab  
Sent monthly reports to the Michigan Department of Health  
Ran auxiliary well generator once a week  
Water meters read for March.

## MAJOR AND LOCAL STREETS

Cleaning up where snow plow messed up tree lawns.  
Doing a lot of cold patch work.

## SEWER SYSTEM

Sewer mains rodded	<u>5</u>
Sewer services dug up and repaired	<u>0</u>

## LIFT STATIONS

Lift stations are running very well at this time  
Generators are run once a week for testing  
Bar screens are cleaned twice a week

## Iron Removal Plant

Run back up generator once a week.  
Back wash twice a week.

# HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.  
621-3022  
Dan Staunton Supt.



4/25/2022

## WATER QUALITY AVERAGE FOR THE MONTH

### Raw Water

Iron	<u>1.54</u>	ppm
Manganese	<u>0.147</u>	ppm
pH	<u>7.7</u>	

### Finished Water

Iron	<u>0</u>	ppm
Manganese	<u>0</u>	ppm
Chlorine	<u>1</u>	ppm
Phosphates	<u>1.2</u>	ppm
Flouride	<u>1</u>	ppm
pH	<u>7.7</u>	

### Chemicals used

	<u>Total Lbs</u>
Chlorine	<u>91</u>
Phosphates	<u>199</u>
Flouride	<u>154</u>

### Average Daily Use

<u>2.9</u>
<u>6.4</u>
<u>4.9</u>

## WATER PUMPED FOR THE MONTH

Backwash water

<u>4.474</u>	Million Gallons
<u>133,000</u>	Gallons

## WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.  
525 E. Main St.  
200 Beachwood St.  
Well # 5

<u>ND</u>
<u>ND</u>
<u>ND</u>
<u>ND</u>