

HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.

621-3022

Dan Staunton Supt.



1/25/2021

MAINTENANCE DEPARTMENT

Serviced all the equipment that required servicing
Repaired all the equipment that required repairing
Haul snow from parking lots
Take down Christmas decorations.
Snow removal as needed

WATER DEPARTMENT

Water turn off	1
Water turn on	2
Water meter repairs	6
Water leaks repaired	1
Water meters read by request	7
Water services replaced to water main	1
Collected monthly water samples and delivered to Paw Paw Lab	
Sent monthly reports to the Michigan Department of Health	
Ran auxiliary well generator once a week	
Water meters read for the month of December	

MAJOR AND LOCAL STREETS

Snow removal as needed.
Did some cold patching

SEWER SYSTEM

Sewer mains rodded	4
Sewer services dug up and repaired	1
B and Z Construction had to dig up sewer line and repair.	

LIFT STATIONS

Lift stations are running very well at this time
Generators are run once a week for testing
Bar screens are cleaned twice a week
Replaced pump one in lift station 372.

IRON REMOVAL PLANT

Run back up generator once a week.
Back wash twice a week.
Replaced transformer in well room

HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.
621-3022
Dan Staunton Supt.



1/25/2021

WATER QUALITY AVERAGE FOR THE MONTH

Raw Water	Finished Water
Iron	1.56 ppm
Manganese	0.161 ppm
pH	7.9
Chemicals used	Total Lbs
Chlorine	96.5
Phosphates	99.5
Flouride	189.6
	Average Daily Use
	3.1
	3.2
	6.1

WATER PUMPED FOR THE MONTH

Backwash water 4.238 Million Gallons

191,000 Gallons

WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.	ND
525 E. Main St.	ND
200 Beachwood St.	ND
Well#4	ND