

HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.

621-3022

Dan Staunton Supt.



7/26/2021

MAINTENANCE DEPARTMENT

Serviced all the equipment that required servicing

Repaired all the equipment that required repairing

Empty trash cans every week.

Clean restrooms every day.

Mow grass as needed.

Mow Waste Water Treatment Plants grass.

Mow all city propertys as needed.

Working with contractors with both constrution projects.

WATER DEPARTMENT

Water turn off

3

Water turn on

1

Water meter repairs

2

Water leaks repaired

2

Water meters read by request

6

Water services replaced to water main

1

Collected monthly water samples and delivered to Paw Paw Lab

Sent monthly reports to the Michigan Department of Health

Ran auxiliary well generator once a week

Water meters read for the month.

MAJOR AND LOCAL STREETS

Cold patching

3

Prospect St. is near completion.

1

SEWER SYSTEM

Sewer mains rodded

2

Sewer services dug up and repaired

3

Replaced 410 ft. sewer main on Linden St.

LIFT STATIONS

Lift stations are running very well at this time

Generators are run once a week for testing

Bar screens are cleaned twice a week

Iron Removal Plant

HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.
621-3022
Dan Staunton Supt.



7/26/2021

WATER QUALITY AVERAGE FOR THE MONTH

Raw Water

Iron	1.51	ppm
Manganese	0.15	ppm
pH	7.7	

Finished Water

Iron	0	ppm
Manganese	0	ppm
Chlorine	1	ppm
Phosphates	1.7	ppm
Flouride	0.8	ppm
pH	7.7	

Chemicals used

Chlorine	143	Total Lbs
Phosphates	118	
Flouride	232	

Average Daily Use

Chlorine	3
Phosphates	3.8
Flouride	7.4

WATER PUMPED FOR THE MONTH

Backwash water 6.010 Million Gallons

212,000 Gallons

WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.	ND
525 E. Main St.	ND
200 Beachwood St.	ND