

HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.
621-3022
Ricky Ricks Supt.



March, 2025

MAINTENANCE DEPARTMENT

Serviced all equipment that required servicing.
Dig up storm drain on Washington St. and repair.
Clean up Park.
Replaced starter on service pickup.
Replaced door on kabota tractor.

WATER DEPARTMENT

Water turn off	1
Water turn on	1
Water meter repairs	4
Water leaks repaired	3
Water meters read by request	8
Water services replaced to water main	1

Collected monthly water samples and delivered to Paw Paw Lab
Sent monthly reports to the Michigan Department of Health
Ran auxiliary well generator once a week

MAJOR AND LOCAL STREETS

Snow removal as needed.
Plow sidewalks as needed.
Cold patching.
Salt icy streets as needed.

SEWER SYSTEM

Sewer mains rodded	4
Sewer services dug up and repaired	1

LIFT STATIONS

Lift stations are running very well at this time
Generators are run once a week for testing
Bar screens are cleaned twice a week

Iron Removal Plant

Run back up generator once a week.

IRON REMOVAL PLANT

62822 Red Arrow Hwy
621-6505
Dan Staunton



March, 2025

WATER QUALITY AVERAGE FOR THE MONTH

Raw Water

Iron 1.42 ppm
Manganese 0.137 ppm
pH 7.2

Finished Water

Iron 0.002 ppm
Manganese 0.003 ppm
Chlorine 1.1 ppm
Phosphates 1 ppm
Flouride 0.8 ppm
pH 7.2

Chemicals used

	<u>Total Lbs</u>
Chlorine	<u>90.3</u>
Phosphates	<u>150</u>
Flouride	<u>123.5</u>

Average Daily Use

	<u>Average Daily Use</u>
Chlorine	<u>6.7</u>
Phosphates	<u>5.3</u>
Flouride	<u>4.4</u>

WATER PUMPED FOR THE MONTH

Backwash water 5.649 Million Gallons

170,000 Gallons

WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.

ND

525 E. Main St.

ND

200 Beachwood St.

ND