

HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.
621-3022
Dan Staunton Supt.



February, 2024

MAINTENANCE DEPARTMENT

Serviced all the equipment that required servicing
Repaired all the equipment that required repairing
Snow removal as needed.
Haul snow from parking lots.
Replace scaper blades on dump trucks.

WATER DEPARTMENT

Water turn off	1
Water turn on	2
Water meter repairs	5
Water leaks repaired	1
Water meters read by request	10
Water services replaced to water main	1
Collected monthly water samples and delivered to Paw Paw Lab	
Sent monthly reports to the Michigan Department of Health	
Ran auxiliary well generator once a week	

MAJOR AND LOCAL STREETS

Snow removal as needed.
Did some cold patching.

SEWER SYSTEM

Sewer mains rodded	3
Sewer services dug up and repaired	1

LIFT STATIONS

Lift stations are running very well at this time
Generators are run once a week for testing
Bar screens are cleaned twice a week

Iron Removal Plant

Run back up generator once a week.
Had pump rebuilt in liftstation 372.

HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.
621-3022
Dan Staunton Supt.



February, 2024

WATER QUALITY AVERAGE FOR THE MONTH

Raw Water

Iron	<u>1.51</u> ppm
Manganese	<u>0.149</u> ppm
pH	<u>7.3</u>

Finished Water

Iron	<u>0</u> ppm
Manganese	<u>0</u> ppm
Chlorine	<u>1</u> ppm
Phosphates	<u>1.3</u> ppm
Flouride	<u>0.7</u> ppm
pH	<u>7.2</u>

Chemicals used

	<u>Total Lbs</u>
Chlorine	<u>106</u>
Phosphates	<u>200</u>
Flouride	<u>168</u>

Average Daily Use

<u>3.4</u>
<u>6.4</u>
<u>5.4</u>

WATER PUMPED FOR THE MONTH

Backwash water

<u>5.280</u> Million Gallons
<u>158,000</u> Gallons

WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.
525 E. Main St.
200 Beachwood St.

<u>ND</u>
<u>ND</u>
<u>ND</u>