

HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.
621-3022
Dan Staunton Supt.



5/23/2022

MAINTENANCE DEPARTMENT

Serviced all the equipment that required servicing
Repaired all the equipment that required repairing
Mow all city lots as needed.
Clean and sweep parking lots.
Picking up brush and leaves.
Mowed Waste Water Treatment Plant
Had Puhrmans push up brush pile at WWTP>

WATER DEPARTMENT

Water turn off	1
Water turn on	1
Water meter repairs	4
Water leaks repaired	1
Water meters read by request	5
Water services replaced to water main	0

Collected monthly water samples and delivered to Paw Paw Lab
Sent monthly reports to the Michigan Department of Health
Ran auxiliary well generator once a week
Water meters read for April.
Flushed fire hydrants.

MAJOR AND LOCAL STREETS

Repaired sink hole on Woodside Drive.
Doing a lot of cold patch work.

SEWER SYSTEM

Sewer mains rodded	4
Sewer services dug up and repaired	0

LIFT STATIONS

Lift stations are running very well at this time
Generators are run once a week for testing
Bar screens are cleaned twice a week

Iron Removal Plant

Run back up generator once a week.
Back wash twice a week.

HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.
621-3022
Dan Staunton Supt.



5/23/2022

WATER QUALITY AVERAGE FOR THE MONTH

Raw Water

Iron 1.52 ppm
Manganese 0.151 ppm
pH 7.6

Finished Water

Iron 0 ppm
Manganese 0 ppm
Chlorine 1 ppm
Phosphates 1.3 ppm
Flouride 0.9 ppm
pH 7.6

Chemicals used

	<u>Total Lbs</u>
Chlorine	<u>97</u>
Phosphates	<u>190</u>
Flouride	<u>165</u>

Average Daily Use

<u>3.2</u>
<u>6.3</u>
<u>5.5</u>

WATER PUMPED FOR THE MONTH

Backwash water

4.800 Million Gallons
170,000 Gallons

WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.
525 E. Main St.
200 Beachwood St.
Well # 5

ND
ND
ND
ND