

# HARTFORD PUBLIC WORKS DEPARTMENT

City of Hartford 621-3022  
Justin Ryan Supt.



9/26/2022

## MAINTENANCE DEPARTMENT

Serviced all the equipment that required servicing  
Repaired all the equipment that required repairing  
Mow all city lots as needed.  
Clean and sweep parking lots.  
Had six trees removed  
Mowed Waste Water Treatment Plant

## WATER DEPARTMENT

Water turn off	<u>1</u>
Water turn on	<u>1</u>
Water meter repairs	<u>3</u>
Water leaks repaired	<u>1</u>
Water meters read by request	<u>4</u>
Water services replaced to water main	<u>3</u>
Collected monthly water samples and delivered to Paw Paw Lab	
Sent monthly reports to the Michigan Department of Health	
Ran auxiliary well generator once a week	
Water meters read for the month	

## MAJOR AND LOCAL STREETS

Had cross walks repaired  
Doing a lot of cold patch work.

## SEWER SYSTEM

Sewer mains rodded	<u>4</u>
Sewer services dug up and repaired	<u>1</u>
Mowed all lift stations	

## LIFT STATIONS

Lift stations are running very well at this time  
Generators are run once a week for testing  
Bar screens are cleaned twice a week

## Iron Removal Plant

Run back up generator once a week.  
Back wash twice a week.

# HARTFORD PUBLIC WORKS DEPARTMENT

200 Beachwood St.  
621-3022  
Dan Staunton Supt.



9/26/2022

## WATER QUALITY AVERAGE FOR THE MONTH

### Raw Water

Iron 1.54 ppm  
Manganese 0.147 ppm  
pH 7.3

### Finished Water

Iron 0 ppm  
Manganese 0 ppm  
Chlorine 1.1 ppm  
Phosphates 1.3 ppm  
Flouride 0.8 ppm  
pH 7.2

### Chemicals used

	<u>Total Lbs</u>
Chlorine	<u>126.2</u>
Phosphates	<u>219</u>
Flouride	<u>200</u>

### Average Daily Use

<u>4</u>
<u>7</u>
<u>6.4</u>

## WATER PUMPED FOR THE MONTH

Backwash water

5.890 Million Gallons  
176,000 Gallons

## WATER BACTI SAMPLES FOR THE MONTH

19 W. Main St.  
525 E. Main St.  
200 Beachwood St.  
Well#6

ND  
ND  
ND  
ND